



*User Guide*

---

# ***SI-DeviceNet***

---

Part Number: 0478-0032-02  
Issue Number: 2



## General Information

The manufacturer accepts no liability for any consequences resulting from inappropriate, negligent or incorrect installation or adjustment of the optional parameters of the equipment or from mismatching the variable speed drive with the motor.

The contents of this guide are believed to be correct at the time of printing. In the interests of commitment to a policy of continuous development and improvement, the manufacturer reserves the right to change the specification of the product or its performance, or the content of the guide without notice.

All rights reserved. No parts of this guide may be reproduced or transmitted in any form or by any means, electrical or mechanical including, photocopying, recording or by an information storage or retrieval system, without permission in writing from the publisher.

## Environmental Statement

Control Techniques is committed to minimising the environmental impacts of its manufacturing operations and of its products throughout their life cycle. To this end, we operate an Environmental Management System (EMS) which is certified to the International Standard ISO 14001. Further information on the EMS, our Environment Policy and other relevant information is available on request, or can be found at [www.greendrives.com](http://www.greendrives.com).

The electronic variable speed drives manufactured by Control Techniques have the potential to save energy and (through increased machine/process efficiency) reduce raw material consumption and scrap throughout their long working lifetime. In typical applications, these positive environmental effects far outweigh the negative impacts of product manufacture and end-of-life disposal.

Nevertheless, when the products eventually reach the end of their useful life, they must not be discarded but should instead be recycled by a specialist recycler of electronic equipment. Recyclers will find the products easy to dismantle into their major component parts for efficient recycling. Many parts snap together and can be separated without the use of tools, while other parts are secured with conventional fasteners. Virtually all parts of the product are suitable for recycling.

Product packaging is of good quality and can be re-used. Large products are packed in wooden crates, while smaller products come in strong cardboard cartons which themselves have a high-recycled fibre content. If not re-used, these containers can be recycled. Polythene, used on the protective film and bags from wrapping product, can be recycled in the same way. Control Techniques' packaging strategy prefers easily recyclable materials of low environmental impact, and regular reviews identify opportunities for improvement.

When preparing to recycle or dispose of any product or packaging, please observe local legislation and best practice.

## Software Statement

This Option module is supplied with the latest software version. When retro-fitting to an existing system, all software versions should be verified to confirm the same functionality as Option modules of the same type already present. This also applies to products returned from a Control Techniques Service Centre or Repair Centre. If there is any doubt please contact the supplier of the product.

The software version of the Option module can be identified by looking at Pr **MM.002** where MM is the relevant menu number for the Option module slot being used. See Pr **MM.002** description later in this manual for more information. The software version takes the form of **ww.xx.yy.zz** seen in **MM.002**.

## REACH legislation

EC Regulation 1907/2006 on the Registration, Evaluation, Authorisation and restriction of Chemicals (REACH) requires the supplier of an article to inform the recipient if it contains more than a specified proportion of any substance which is considered by the European Chemicals Agency (ECHA) to be a Substance of Very High Concern (SVHC) and is therefore listed by them as a candidate for compulsory authorisation.

For current information on how this requirement applies in relation to specific Control Techniques products, please approach your usual contact in the first instance. Control Techniques position statement can be viewed at:

<http://www.controltechniques.com/REACH>

Copyright : © January 2013 Control Techniques Ltd.

Issue Number : 1

For patent and intellectual property related information please go to [www.ctpatents.info](http://www.ctpatents.info)

---

# Contents


---

|          |   |           |
|----------|---|-----------|
| <b>1</b> | <b>Safety information .....</b>                 | <b>5</b>  |
| 1.1      | Warnings, Cautions and Notes .....              | 5         |
| 1.2      | Electrical safety - general warning .....       | 5         |
| 1.3      | System design and safety of personnel .....     | 5         |
| 1.4      | Environmental limits .....                      | 6         |
| 1.5      | Compliance with regulations .....               | 6         |
| 1.6      | Adjusting parameters .....                      | 6         |
| <b>2</b> | <b>Introduction .....</b>                       | <b>7</b>  |
| 2.1      | What Is DeviceNet? .....                        | 7         |
| 2.2      | What is SI-DeviceNet? .....                     | 9         |
| 2.3      | General specification .....                     | 9         |
| 2.4      | Back-up power supply .....                      | 9         |
| 2.5      | Option Module identification .....              | 10        |
| 2.6      | Product Conformance Certificate .....           | 10        |
| 2.7      | Conventions used in this guide .....            | 10        |
| <b>3</b> | <b>Mechanical installation .....</b>            | <b>11</b> |
| 3.1      | General installation .....                      | 11        |
| <b>4</b> | <b>Electrical installation .....</b>            | <b>12</b> |
| 4.1      | SI-DeviceNet terminal descriptions .....        | 12        |
| 4.2      | SI-DeviceNet connections .....                  | 13        |
| 4.3      | DeviceNet cable .....                           | 13        |
| 4.4      | DeviceNet network termination .....             | 14        |
| 4.5      | SI-DeviceNet cable shield connections .....     | 14        |
| 4.6      | DeviceNet ground point .....                    | 15        |
| 4.7      | Maximum network length .....                    | 15        |
| 4.8      | Spurs .....                                     | 15        |
| 4.9      | Minimum node to node cable length .....         | 15        |
| <b>5</b> | <b>Getting started .....</b>                    | <b>16</b> |
| 5.1      | Quick start chart SI-DeviceNet .....            | 17        |
| 5.2      | Parameter save and restore .....                | 18        |
| 5.3      | Module reset .....                              | 18        |
| 5.4      | Restoring module parameter default values ..... | 18        |
| 5.5      | Single Line Parameters .....                    | 18        |
| <b>6</b> | <b>Parameters .....</b>                         | <b>25</b> |
| 6.1      | Menus .....                                     | 25        |
| 6.2      | Module menu 0 - Module Information .....        | 25        |
| 6.3      | Module menu 1 - DeviceNet Setup .....           | 28        |
| 6.4      | Module menu 2 - Input Mappings .....            | 40        |
| 6.5      | Module menu 3 - Output Mappings .....           | 41        |
| 6.6      | Module menu 4 - Fault Values .....              | 42        |
| <b>7</b> | <b>Non cyclic data .....</b>                    | <b>44</b> |
| 7.1      | Introduction .....                              | 44        |
| 7.2      | Explicit parameter access .....                 | 44        |


|           |  |           |
|-----------|--|-----------|
| <b>8</b>  | <b>Control / status word .....</b>       | <b>45</b> |
| 8.1       | What are control and status words? ..... | 45        |
| 8.2       | Control word .....                       | 45        |
| 8.3       | Status word .....                        | 47        |
| <b>9</b>  | <b>EDS Files .....</b>                   | <b>49</b> |
| 9.1       | What are EDS files? .....                | 49        |
| 9.2       | Generic EDS files .....                  | 49        |
| <b>10</b> | <b>Advanced Features .....</b>           | <b>50</b> |
| 10.1      | Supported Drive assembly objects .....   | 50        |
| <b>11</b> | <b>DeviceNet Objects .....</b>           | <b>54</b> |
| 11.1      | Identity Object .....                    | 54        |
| 11.2      | SI-DeviceNet Object .....                | 57        |
| 11.3      | Motor Data Object .....                  | 59        |
| 11.4      | Control Supervisor .....                 | 62        |
| 11.5      | AC/DC Drive Object .....                 | 65        |
| 11.6      | Control Techniques Object .....          | 68        |
| <b>12</b> | <b>Diagnostics .....</b>                 | <b>69</b> |
| 12.1      | Overview .....                           | 69        |
| <b>13</b> | <b>Glossary Of Terms .....</b>           | <b>73</b> |

# 1 Safety information

## 1.1 Warnings, Cautions and Notes



A **Warning** contains information, which is essential for avoiding a safety hazard.



A **Caution** contains information, which is necessary for avoiding a risk of damage to the product or other equipment.

**NOTE** A **Note** contains information which helps to ensure correct operation of the product.

## 1.2 Electrical safety - general warning

The voltages used in the drive can cause severe electrical shock and/or burns, and could be lethal. Extreme care is necessary at all times when working with or adjacent to the drive.

Specific warnings are given at the relevant places in this User Guide.

## 1.3 System design and safety of personnel

The drive is intended as a component for professional incorporation into complete equipment or a system. If installed incorrectly, the drive may present a safety hazard. The drive uses high voltages and currents, carries a high level of stored electrical energy, and is used to control equipment which can cause injury. Close attention is required to the electrical installation and the system design to avoid hazards either in normal operation or in the event of equipment malfunction. System design, installation, Commissioning/start-up and maintenance must be carried out by personnel who have the necessary training and experience. They must read this safety information and this User Guide carefully.

The STOP and SAFE TORQUE Off functions of the drive do not isolate dangerous voltages from the output of the drive or from any external option unit. The supply must be disconnected by an approved electrical isolation device before gaining access to the electrical connections.

**With the sole exception of the SAFE TORQUE Off function, none of the drive functions must be used to ensure safety of personnel, i.e. they must not be used for safety-related functions.**

Careful consideration must be given to the functions of the drive which might result in a hazard, either through their intended behavior or through incorrect operation due to a fault. In any application where a malfunction of the drive or its control system could lead to or allow damage, loss or injury, a risk analysis must be carried out, and where necessary, further measures taken to reduce the risk - for example, an over-speed protection device in case of failure of the speed control, or a fail-safe mechanical brake in case of loss of motor braking.

**The system designer is responsible for ensuring that the complete system is safe and designed correctly according to the relevant safety standards.**

## 1.4 Environmental limits

Instructions in the *Unidrive M User Guide* regarding transport, storage, installation and use of the drive must be complied with, including the specified environmental limits. Drives must not be subjected to excessive physical force.

## 1.5 Access

Drive access must be restricted to authorized personnel only. Safety regulations which apply at the place of use must be complied with.

## 1.6 Compliance with regulations

The installer is responsible for complying with all relevant regulations, such as national wiring regulations, accident prevention regulations and electromagnetic compatibility (EMC) regulations. Particular attention must be given to the cross-sectional areas of conductors, the selection of fuses or other protection, and protective earth (ground) connections.

The *Unidrive M User Guide* contains instructions for achieving compliance with specific EMC standards.

Within the European Union, all machinery in which this product is used must comply with the following directives:

- 2006/42/EC: Safety of machinery.
- 2004/108/EC: Electromagnetic Compatibility.

## 1.7 Adjusting parameters

Some parameters have a profound effect on the operation of the drive. They must not be altered without careful consideration of the impact on the controlled system.

Measures must be taken to prevent unwanted changes due to error or tampering.

### 1.7.1 Stored charge

The drive contains capacitors that remain charged to a potentially lethal voltage after the AC supply has been disconnected. If the drive has been energized, the AC supply must be isolated at least ten minutes before work may continue.

## 2 Introduction

### 2.1 What Is DeviceNet?

DeviceNet is a networking system that falls into the generic category of Fieldbus. Fieldbuses are generally defined as industrial networking systems that are intended to replace traditional wiring systems. Figure 2-1 shows the traditional cabling requirements to transfer signals between a controller and two nodes.

**Figure 2-1 SI-DeviceNet Traditional cable layout**




Table 2.1 details how the wiring is used to communicate data between the controller and the nodes. Each signal that is communicated requires one signal wire giving a total of 66 signal wires plus a 0V return.


**Table 2.1 Traditional wiring details**

| Number of signals | Type            | Source / Destination  | Description     |
|-------------------|-----------------|-----------------------|-----------------|
| 16                | digital inputs  | node 1 to master      | status signals  |
|                   | digital outputs | controller to slave 1 | control signals |
| 1                 | analog output   | controller to slave 1 | control signal  |
| 16                | digital inputs  | node 2 to master      | status signals  |
|                   | digital outputs | controller to slave 2 | control signals |
| 1                 | analog output   | controller to slave 2 | control signal  |

A fieldbus topology such as DeviceNet allows the same configuration to be realised using only 2 signal wires plus a shield and power. This method of communication saves significantly on the amount of cabling required and can improve overall system reliability, as the number of inter-connections is greatly reduced.

Figure 2-2 shows a typical DeviceNet system transferring the same signals as given in the traditionally wired example. The signals are now transmitted by converting them into a serial data stream which is received by the master as if they were connected using traditional wiring. The data stream on DeviceNet allows up to 56 (28 *input* and 28 *output*) independent values to be sent or received by the master, there are also methods available (non-cyclic data) to allow random access to drive parameters.

**Figure 2-2 DeviceNet overview**



**Table 2.2 Data mappings for SI-DeviceNet**

| Number of network words | Type            | Source / Destination | Description     |
|-------------------------|-----------------|----------------------|-----------------|
| 1                       | digital inputs  | slave 1 to master    | status signals  |
|                         | digital outputs | master to slave 1    | control signals |
|                         | analog output   | master to slave 1    | control signal  |
|                         | digital inputs  | slave 2 to master    | status signals  |
|                         | digital outputs | master to slave 2    | control signals |
|                         | analog output   | master to slave 2    | control signal  |



Table 2.2 details the number of data words used to communicate the signals using the DeviceNet network. It can be seen that the resulting reduction in cabling is significant. DeviceNet can transfer data using two distinct modes. The first of these modes is cyclic where signals are sent in predefined blocks at regular intervals. This is the equivalent of the hard-wired example above in Figure 2-1.

The second method of transfer is called non-cyclic data and is used for sending values that only need to be changed occasionally or where the source or destination of the signal changes; this is the equivalent of a temporary patch lead that is removed after use.

## 2.2 What is SI-DeviceNet?

SI-DeviceNet is a fieldbus Option Module which can be installed to the expansion slot(s) in Unidrive M to provide DeviceNet slave connectivity.

It is possible to use more than one SI-DeviceNet or a combination of SI-DeviceNet and other Option Modules to provide additional functionality such as extended I/O, gateway functionality, or additional PLC features.

**Figure 2-3 SI-DeviceNet Option Module**



## 2.3 General specification

- Supported data rates (bits per s): 500 k, 250 k, 125 k.
- 1 to 28 input/output polled data words supported.
- Explicit communications (non-cyclic) provides access to all drive parameters.
- 8 pre-defined DeviceNet profiles supported.

## 2.4 Back-up power supply

The required drive can be connected to a back-up power supply. This keeps the control electronics and Option Module powered up, allowing the SI-DeviceNet to continue communicating with the DeviceNet master controller when the line power to the drive is switched off.

**NOTE**

The back-up supply is provided through the drive and not the connections on SI-DeviceNet, which have an alternative use.

## 2.5 Option Module identification

SI-DeviceNet can be identified by:

1. The label located on the top of the Option Module.
2. The color coding across the front of the SI-DeviceNet (dark grey).

**Figure 2-4 SI-DeviceNet labels**



1 Topside module label

2 Underside module label

### 2.5.1 Date code format

The date code is split into two sections: a letter followed by a number. The letter indicates the year, and the number indicates the week number (within the year) in which the Option Module was built. The letters go in alphabetical order, starting with A in 1990 (B in 1991, C in 1992 etc).

**Example:**

A date code of V35 would correspond to week 35 of year 2012.

## 2.6 Product Conformance Certificate

SI-DeviceNet has been awarded full DeviceNet Conformance Certification by the Open DeviceNet Vendors Association (ODVA). A copy of the certificate is available on request from your supplier or local Control Techniques Drive Centre.

## 2.7 Conventions used in this guide

The configuration of the host drive and Option Module is done using menus and parameters. A menu is a logical collection of parameters that have similar functionality. In the case of an Options Module, the parameters will appear in menu 15, 16 or 17 depending on which slot the module is installed to. The menu is determined by the number before the decimal point.

The method used to determine the menu or parameter is as follows:

- Pr **S.mm.ppp** - Where S signifies the Option module slot number and mm.ppp signifies the menu and parameter number of the Option module's internal menus and parameters.
- Pr **MM.ppp** - Where MM signifies the menu allocated to the Option module set-up menu and ppp signifies the parameter number.
- Pr **mm.000** - Signifies parameter number 000 in any drive menu.

# 3 Mechanical installation




Before installing or removing an Option module from any drive, ensure the AC supply has been disconnected for at least 10 minutes and refer to section 1 *Safety information* on page 5. If using a DC bus supply ensure this is fully discharged before working on any drive or Option module.

## 3.1 General installation

The installation of an Option module is illustrated in Figure 3-1.

Figure 3-1 Installing an Option module



### 3.1.1 Installing the first Option module

- Option module slots must be used in the following order: slot 3, slot 2 and slot 1. Orientate the Option module above the drive as shown in (1).
- Align and insert the Option module tab into the slot (2). Press down on the Option module until it clicks into place.

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

## 4 Electrical installation

### 4.1 SI-DeviceNet terminal descriptions

SI-DeviceNet has a standard 5-way screw terminal block connector (shown on the right) for the DeviceNet network.

Figure 4-1 SI-DeviceNet - connector view




Table 4.1 SI-DeviceNet terminal descriptions

| 5-way terminal | Function | Description                     |
|----------------|----------|---------------------------------|
| 1              | 0 V      | 0 V DeviceNet external supply   |
| 2              | CAN-L    | Negative data line              |
| 3              | Shield   | Cable braided shield connection |
| 4              | CAN-H    | Positive data line              |
| 5              | +24 V    | +24 V DeviceNet external supply |

**NOTE**

The external supply terminals provide power for the DeviceNet transceiver circuitry, but do NOT provide power to keep the SI-DeviceNet operating in the event of the mains power supply loss to the drive. An external supply will keep the DeviceNet transceivers powered up and the network load characteristics constant in the event of loss of power to the drive.




**CAUTION**

Any external supply must be suitably installed to prevent noise on the network. Connecting pins 1 and 5 to an external supply allows the line driver circuitry to remain powered when the drive and the SI-DeviceNet module are turned off. This 24 V input does not allow SI-DeviceNet to continue communicating.

## 4.2 SI-DeviceNet connections

To connect SI-DeviceNet to the DeviceNet network, make the connections as shown in the diagram below. The length of the "pigtail" shield connection must be kept as short as possible.

**Figure 4-2 SI-DeviceNet connections**



## 4.3 DeviceNet cable

DeviceNet cable has 2 twisted pairs plus an overall shielding. DeviceNet has a specified color code, and it is important that this code is maintained. The data wires are white and blue, and the network power supply wires are red and black.

**Table 4.2 DeviceNet cable color codes**

| Terminal | Cable          | Data signal | Description                 |
|----------|----------------|-------------|-----------------------------|
| 1        | Black          | 0V          | 0 V external power supply   |
| 2        | Blue           | CAN-L       | Negative data line          |
| 3        | Braided Shield | Shield      | Cable shield                |
| 4        | White          | CAN-H       | Positive data line          |
| 5        | Red            | +24 V       | +24 V external power supply |

DeviceNet networks run at high data rates and require cable specifically designed to carry high frequency signals. Low quality cable will attenuate the signals and may render the signal unreadable for the other nodes on the network. Cable specifications and a list of approved manufacturers of cable for use on DeviceNet networks is available on the Open DeviceNet Vendors Association web site at [www.odva.org](http://www.odva.org).


**NOTE** Control Techniques can only guarantee correct and reliable operation of SI-DeviceNet if all other equipment installed on the DeviceNet network (including the network cable) has been approved by the ODVA.

## 4.4 DeviceNet network termination

It is very important in high-speed communications networks that the network communications cable is installed with the specified termination resistor network at each end of the cable segment. This prevents signals from being reflected back down the cable and causing interference.

During installation of a DeviceNet network, 120  $\Omega$  0.25 W termination resistors should be installed across the CAN-H and CAN-L lines at both ends of the network segment, as shown in Figure 4-3 below.

**Figure 4-3 DeviceNet network termination**



**NOTE**

Failure to terminate a network correctly can seriously affect the operation of the network. If the correct termination resistors are not installed, the noise immunity of the network is greatly reduced.

If too many termination resistors are installed on a DeviceNet network, the network will be over-loaded, resulting in reduced signal levels. This may cause nodes to miss some bits of information, resulting in potential transmission errors.

## 4.5 SI-DeviceNet cable shield connections

The SI-DeviceNet should be wired with the cable shields isolated from ground at each drive. The cable shields should be linked together at the point where they emerge from the cable, and formed into a short pigtail to be connected to pin 3 on the DeviceNet connector.

**NOTE**

The DeviceNet cable can be tie-wrapped to the grounding bar or local convenient mounting that is not live to provide strain relief, but the DeviceNet cable shield must be kept isolated from ground at each node. The only exception to this is the DeviceNet ground point. Refer to section 4.6 *DeviceNet ground point* on page 15.

## 4.6 DeviceNet ground point

The DeviceNet cable shield must be grounded AT ONE POINT only, usually near the centre point of the cable run. This is to prevent the cable shield from becoming live in the event of catastrophic failure of another device on the DeviceNet network.

## 4.7 Maximum network length

The maximum number of nodes that can be connected to a single DeviceNet network segment is 64. The maximum length of network cable for a DeviceNet network is specified by the *Open DeviceNet Vendors Association* and depends on the data rate to be used.

**Table 4.3 DeviceNet maximum segment lengths**

| Data rate (bits/sec) | Maximum network length (m) |
|----------------------|----------------------------|
| 1 M                  | 30                         |
| 800 k                | 50                         |
| 500 k                | 100                        |
| 250 k                | 250                        |
| 125 k                | 500                        |
| 100 k                | 700                        |
| 50 k                 | 1000                       |
| 20 k                 | 2500                       |
| 10 k                 | 5000                       |

## 4.8 Spurs

Control Techniques do not recommend the use of spurs on a DeviceNet network.

## 4.9 Minimum node to node cable length

The DeviceNet specification does not specify a minimum node to node distance, however, Control Techniques advises a minimum distance of 1 m between nodes to prevent excessive bend radii and to reduce network reflections.

---

## 5 Getting started

---

This section is intended to provide a generic guide for setting up SI-DeviceNet and a master controller/PLC. Figure 5.1 *Quick start chart SI-DeviceNet* on page 17 is intended as the starting point for a new installation. The following pages detail the various methods available to configure SI-DeviceNet. It is recommended that all of this section is read, before attempting to configure a system.

**NOTE** It is recommended that the latest firmware is used where possible to ensure all features are supported.


**NOTE** Due to the large number of different PLCs/masters that support DeviceNet, details cannot be provided for any specific master or PLC. Generic support is available through your supplier or local drive centre. Before contacting your supplier or local drive centre for support ensure you have read Chapter 12 *Diagnostics* on page 69 of this manual and check you have configured all parameters correctly.

Ensure the following information is available before calling:

- A list of all parameters in SI-DeviceNet
- The drive firmware version (*see the drive documentation*)
- The SI-DeviceNet firmware version



# 5.1 Quick start chart SI-DeviceNet



|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| <b>Getting started</b>  |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

## 5.2 Parameter save and restore

Parameters in the module are saved when a normal drive parameter save is initiated by selecting "Save Parameters" or setting a value of 1000 in Pr **mm.000** and performing a drive reset. (If the drive is in the under voltage state or is supplied from a low voltage power supply then a value of 1001 must be set in Pr **mm.000** and a drive reset performed).

Any user-saved parameters in the option module's internal menus are stored in non-volatile memory on the module and not in the drive. Therefore, if the module is moved to a different slot or to a different drive, then any saved parameter values will follow the module. If a module is to be replaced, ensure that the parameter values for the module have been backed up before replacing it.

## 5.3 Module reset

A reset of the SI-DeviceNet module can be performed by the methods detailed below.

- Set Pr **S.00.007** (or Pr **MM.007**) to On (1). This will only reset the module in slot S.
- Select "Reset modules" or set a value of 1070 in Pr **mm.000**, and performing a drive reset. This will perform a reset of all option modules installed in the drive.

## 5.4 Restoring module parameter default values

Setting Pr **S.00.008** (or Pr **MM.008**) to On (1) and performing a module reset will return all parameters in the SI-DeviceNet module to their default values.

Parameters in the SI-DeviceNet module will also be set to their default values when drive parameters are returned to their default values.

## 5.5 Single Line Parameters

Table 5.1 Menu 0 Setup

| Parameter     |                  | Range(†)   | Default(⇒) | Type |     |    |    |    |  |
|---------------|------------------|--|------------|------|-----|----|----|----|--|
| <b>MM.001</b> | Module ID        | 0 to 999   | 447        | RO   | Num | ND | NC | PT |  |
| <b>MM.002</b> | Software Version | 00.00.00.00<br>to<br>99.99.99.99                   |            | RO   | Num | ND | NC | PT |  |
| <b>MM.003</b> | Hardware Version | 00.00 to 99.99                                     |            | RO   | Num | ND | NC | PT |  |
| <b>MM.004</b> | Serial Number LS | 0 to 99999999                                      |            | RO   | Num | ND | NC | PT |  |
| <b>MM.005</b> | Serial Number MS | 0 to 99999999                                      |            | RO   | Num | ND | NC | PT |  |
| <b>MM.006</b> | Module status    | Initialising (0), OK (1),<br>Config (2), Error (3) |            | RO   | Num | ND | NC | PT |  |
| <b>MM.007</b> | Module reset     | Off (0) or On (1)                                  | Off (0)    | RW   | Bit |    | NC |    |  |
| <b>MM.008</b> | Module default   | Off (0) or On (1)                                  | Off (0)    | RW   | Bit |    | NC |    |  |

**Table 5.2 Menu 1 DeviceNet setup**

| Parameter |                                     | Range(⇩)   | Default(⇄)    | Type |     |    |    |    |    |
|-----------|-------------------------------------|--|---------------|------|-----|----|----|----|----|
| S.01.001  | Enable DeviceNet Interface          | Off (0) or On (1)  | On (1)        | RO   | Bit |    | NC |    |    |
| S.01.002  | Reset DeviceNet Interface           | Off (0) or On (1)  | Off (0)       | RW   | Bit |    | NC |    |    |
| S.01.003  | Default DeviceNet Interface         | Off (0) or On (1)  | Off (0)       | RW   | Bit |    | NC |    |    |
| S.01.004  | DeviceNet node address              | 0 to 63  | 63            | RW   | Num |    |    |    | US |
| S.01.005  | Baud rate                           | Auto Detect (-1), 125 kbps (0), 250 kbps (1), 500 kbps (2)   | 125 kbps (0)  | RW   | Txt |    |    |    | US |
| S.01.006  | DeviceNet Network Diagnostic        | Network OK (0), Init OK (1), No Cyclic (2), Init Failed (3), Comm Fault (4), No 24 V (5), Baud detecting (6), Initialising (7)   |               | RO   | Txt | ND | NC | PT |    |
| S.01.007  | Cyclic data transfers per second    | 0 to 9999 messages/s   |               | RO   | Num | ND | NC | PT |    |
| S.01.010  | Timeout delay                       | 0 to 9999 ms   | 200 ms        | RW   | Num |    |    |    | US |
| S.01.011  | Timeout action                      | Trip (0), Send fit values (1), Clear output (2), Hold last (3), No action (4)  | Trip (0)      | RW   | Txt |    |    |    | US |
| S.01.012  | Timeout event destination           | This slot (0), Slot 1 (1), Slot 2 (2), Slot 3 (3), Slot 4 (4)  | This slot (0) | RW   | Txt |    |    |    | US |
| S.01.013  | Timeout event                       | No event (0), Event 0 (1), Event 1 (2), Event 2 (3), Event 3 (4), Event 4 (5)  | No event (0)  | RW   | Txt |    |    |    | US |
| S.01.014  | Data alignment                      | 32 (0) or 16 (1) bits  | 32 (0) bits   | RW   | Txt |    |    |    | US |
| S.01.018  | Input Cyclic Assembly Object ID     | 70-73, 106-160 (even)  | 112           | RW   | Num |    |    |    | US |
| S.01.019  | Output Cyclic Assembly Object ID    | 20-23, 107-161 (odd)   | 113           | RW   | Num |    |    |    | US |
| S.01.020  | Input cyclic mapping length         | 1 to 28  | 4             | RO   | Num |    |    |    |    |
| S.01.021  | Output cyclic mapping length        | 1 to 28  | 4             | RO   | Num |    |    |    |    |
| S.01.022  | Input mapping status                | No error (0), Par Impossible (1), Hole in mapping (2), Dup mapping (3), Length exceed (4), Obj not support (5), Pre & uncompress (6), Type Unmatched (7), Memory fault (8), No mapping (9) | No error (0)  | RO   | Txt |    | NC | PT |    |
| S.01.023  | Output mapping status               | No error (0), Par Impossible (1), Hole in mapping (2), Dup mapping (3), Length exceed (4), Obj not support (5), Pre & uncompress (6), Type Unmatched (7), Memory fault (8), No mapping (9) | No error (0)  | RO   | Txt |    | NC | PT |    |
| S.01.024  | Input processing time               | 0 to 65535 ms  |               | RO   | Num | ND |    |    |    |
| S.01.025  | Output processing time              | 0 to 65535 ms  |               | RO   | Num | ND |    |    |    |
| S.01.026  | Input consistency enable            | Disable (0) or Enable (1)  | Disable (0)   | RW   | Bit |    |    |    | US |
| S.01.027  | Input consistency trigger parameter | 0 to 4.99.999  | 0.00.000      | RW   | DE  |    |    | PT | US |

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

|                 |                                      |   |                |    |     |  |  |    |    |
|-----------------|--------------------------------------|---|----------------|----|-----|--|--|----|----|
| <b>S.01.028</b> | Output consistency enable            | Disable (0) or Enable (1)   | Disable (0)    | RW | Bit |  |  |    | US |
| <b>S.01.029</b> | Output consistency trigger parameter | 0 to 4.99.999   | 0.00.000       | RW | DE  |  |  | PT | US |
| <b>S.01.031</b> | Custom product type                  | Unidrive M (0) or Unidrive SP (1)   | Unidrive M (0) | RW | Txt |  |  |    | US |
| <b>S.01.032</b> | Custom product version               | 0 to 9999   | 0              | RW | Num |  |  |    | US |
| <b>S.01.034</b> | Bus Off trip                         | Enable (0) or Disable (1)   | Enable (0)     | RW | Txt |  |  |    | US |
| <b>S.01.040</b> | Motor 1 Type                         | FC DC Motor (2), WRI motor (6), SCI motor (7), Sin PM BL motor (9), Trap PM BL motor (10) | SCI motor (7)  | RO | Txt |  |  | PT | US |
| <b>S.01.041</b> | Motor 2 Type                         | FC DC Motor (2), WRI motor (6), SCI motor (7), Sin PM BL motor (9), Trap PM BL motor (10) | SCI motor (7)  | RO | Txt |  |  | PT | US |

**Table 5.3 Menu 2 Input mapping**

| Parameter |                            | Range(☞)    | Default(⇔) | Type |     |    |  |    |    |
|-----------|----------------------------|-------------|------------|------|-----|----|--|----|----|
| S.02.001  | Input mapping parameter 1  | 0 to 499999 | 10040      | RW   | Num | DE |  | PT | US |
| S.02.002  | Input mapping parameter 2  | 0 to 499999 | 2001       | RW   | Num | DE |  | PT | US |
| S.02.003  | Input mapping parameter 3  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.004  | Input mapping parameter 4  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.005  | Input mapping parameter 5  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.006  | Input mapping parameter 6  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.007  | Input mapping parameter 7  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.008  | Input mapping parameter 8  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.009  | Input mapping parameter 9  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.010  | Input mapping parameter 10 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.011  | Input mapping parameter 11 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.012  | Input mapping parameter 12 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.013  | Input mapping parameter 13 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.014  | Input mapping parameter 14 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.015  | Input mapping parameter 15 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.016  | Input mapping parameter 16 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.017  | Input mapping parameter 17 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.018  | Input mapping parameter 18 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.019  | Input mapping parameter 19 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.020  | Input mapping parameter 20 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.021  | Input mapping parameter 21 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.022  | Input mapping parameter 22 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.023  | Input mapping parameter 23 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.024  | Input mapping parameter 24 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.025  | Input mapping parameter 25 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.026  | Input mapping parameter 26 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.027  | Input mapping parameter 27 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.02.028  | Input mapping parameter 28 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |

|                         |
|-------------------------|
| Safety information      |
| Introduction            |
| Mechanical installation |
| Electrical installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

**Table 5.4 Menu 3 Output mapping**

| Parameter |                             | Range(⇅)    | Default(⇔) | Type |     |    |  |    |    |
|-----------|-----------------------------|-------------|------------|------|-----|----|--|----|----|
| S.03.001  | Output mapping parameter 1  | 0 to 499999 | 6042       | RW   | Num | DE |  | PT | US |
| S.03.002  | Output mapping parameter 2  | 0 to 499999 | 1021       | RW   | Num | DE |  | PT | US |
| S.03.003  | Output mapping parameter 3  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.004  | Output mapping parameter 4  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.005  | Output mapping parameter 5  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.006  | Output mapping parameter 6  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.007  | Output mapping parameter 7  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.008  | Output mapping parameter 8  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.009  | Output mapping parameter 9  | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.010  | Output mapping parameter 10 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.011  | Output mapping parameter 11 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.012  | Output mapping parameter 12 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.013  | Output mapping parameter 13 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.014  | Output mapping parameter 14 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.015  | Output mapping parameter 15 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.016  | Output mapping parameter 16 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.017  | Output mapping parameter 17 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.018  | Output mapping parameter 18 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.019  | Output mapping parameter 19 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.020  | Output mapping parameter 20 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.021  | Output mapping parameter 21 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.022  | Output mapping parameter 22 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.023  | Output mapping parameter 23 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.024  | Output mapping parameter 24 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.025  | Output mapping parameter 25 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.026  | Output mapping parameter 26 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.027  | Output mapping parameter 27 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |
| S.03.028  | Output mapping parameter 28 | 0 to 499999 | 0          | RW   | Num | DE |  | PT | US |

**Table 5.5 Menu 4 Fault values**

| Parameter |                       | Range(⇕)                               | Default(⇔) | Type |     |  |  |  |    |
|-----------|-----------------------|--|------------|------|-----|--|--|--|----|
| S.04.001  | Output Fault value 1  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.002  | Output Fault value 2  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.003  | Output Fault value 3  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.004  | Output Fault value 4  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.005  | Output Fault value 5  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.006  | Output Fault value 6  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.007  | Output Fault value 7  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.008  | Output Fault value 8  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.009  | Output Fault value 9  | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.010  | Output Fault value 10 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.011  | Output Fault value 11 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.012  | Output Fault value 12 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.013  | Output Fault value 13 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.014  | Output Fault value 14 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.015  | Output Fault value 15 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.016  | Output Fault value 16 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.017  | Output Fault value 17 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.018  | Output Fault value 18 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.019  | Output Fault value 19 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.020  | Output Fault value 20 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.021  | Output Fault value 21 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.022  | Output Fault value 22 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.023  | Output Fault value 23 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.024  | Output Fault value 24 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.025  | Output Fault value 25 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.026  | Output Fault value 26 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.027  | Output Fault value 27 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |
| S.04.028  | Output Fault value 28 | -2 <sup>31</sup> to 2 <sup>31</sup> -1 | 0          | RW   | Num |  |  |  | US |

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

**Table 5.6 Menu 9 Resources**

| Parameter       |                 | Range(†)       | Default(⇒) | Type |     |    |    |    |  |
|-----------------|-----------------|----------------|------------|------|-----|----|----|----|--|
| <b>S.09.030</b> | PCB temperature | -128 to 127 °C |            | RO   | Num | ND | NC | PT |  |



# 6 Parameters

## 6.1 Menus

Table 6.1 below details each of the module's internal menus.

**Table 6.1 SI-DeviceNet Internal Menu descriptions**

| Menu       | Description        |
|------------|--------------------|
| <b>S.0</b> | Module information |
| <b>S.1</b> | DeviceNet setup    |
| <b>S.2</b> | Input mapping      |
| <b>S.3</b> | Output mappings    |
| <b>S.4</b> | Fault values       |
| <b>S.9</b> | Resources          |

S is the slot number where the module is installed.

The module's menu 0 is also displayed in menu 15, 16 or 17 on the drive depending on which slot the module is installed in. Table 6.2 below shows the location of module's menu 0 on the drive.

**Table 6.2 SI-DeviceNet menu 0 locations on the drive**

| Slot number | Menu 0 location |
|-------------|-----------------|
| 1           | 15              |
| 2           | 16              |
| 3           | 17              |

## 6.2 Module menu 0 - Module Information

All parameters in **S.00.ppp** (i.e. menu 0 within the Option module menus) are also present in menus 15, 16 or 17 depending on the slot that the module is installed to e.g. Pr **3.00.007** is also present as **17.007**.

The functionality and properties of the parameters are identical between the two menus.

| Module ID code  |         |          |
|-----------------|---------|----------|
| <b>S.00.001</b> | Default | 447      |
|                 | Range   | 0 to 999 |
|                 | Access  | RO       |

Pr **S.00.001** displays the ID number for the Option Module. For SI-DeviceNet, this is 447.

| SI-DeviceNet firmware version |         |                            |
|-------------------------------|---------|----------------------------|
| <b>S.00.002</b>               | Default | N/A                        |
|                               | Range   | 00.00.00.00 to 99.99.99.99 |
|                               | Access  | RO                         |

The firmware version of the Option module is in the format of **ww.xx.yy.zz**

| SI-DeviceNet hardware version |         |                |
|-------------------------------|---------|----------------|
| <b>S.00.003</b>               | Default | N/A            |
|                               | Range   | 00.00 to 99.99 |
|                               | Access  | RO             |

The hardware version of the Option module is in the format of **yy.zz**

| Serial Number LS |         |               |
|------------------|---------|---------------|
| <b>S.00.004</b>  | Default | N/A           |
|                  | Range   | 0 to 99999999 |
|                  | Access  | RO            |

| Serial Number MS |         |               |
|------------------|---------|---------------|
| <b>S.00.005</b>  | Default | N/A           |
|                  | Range   | 0 to 99999999 |
|                  | Access  | RO            |

The module serial number is available as a pair of 32-bit values where Serial Number LS (Pr **S.00.004**) provide the least significant 8 decimal digits, and Serial Number MS (Pr **S.00.005**) provides the most significant 8 decimal digits. The reconstructed serial number is  $((\mathbf{S.00.005} \times 100000000) + \mathbf{S.00.004})$ . For example serial number "0001234567898765" would be stored as **S.00.005** = 12345 and **S.00.004** = 67898765.

| Module Status   |         |                               |
|-----------------|---------|-------------------------------|
| <b>S.00.006</b> | Default | N/A                           |
|                 | Range   | Initializing (0) to Error (3) |
|                 | Access  | RO                            |

This parameter displays the current status of the module. All possible values are shown in the table below.

| Value | Text         | Description   |
|-------|--------------|---|
| 0     | Initializing | Module is currently initializing.   |
| 1     | Ok           | Module has initialized and has found no errors.   |
| 2     | Config       | A configuration error has been detected in one of the communications protocols or user program. |
| 3     | Error        | An error has occurred preventing the firmware or user program from running correctly.           |

| Reset module    |         |                   |
|-----------------|---------|-------------------|
| <b>S.00.007</b> | Default | Off (0)           |
|                 | Range   | Off (0) or On (1) |
|                 | Access  | RW                |

Changes to the SI-DeviceNet configuration will not take effect until the SI-DeviceNet has been reset.

To reset the SI-DeviceNet:

- Set Pr **S.00.007** to On (1).
- When the sequence has been completed, Pr **S.00.007** will be reset to Off (0).
- The SI-DeviceNet will reset using the updated configuration.

**NOTE**

This sequence does NOT store the SI-DeviceNet configuration parameters in the drive or the SI-DeviceNet flash memory. This parameter will change back to Off immediately, and as such the change may not be visible on the display.

| Default DeviceNet Interface |         |                   |
|-----------------------------|---------|-------------------|
| <b>S.00.008</b>             | Default | Off (0)           |
|                             | Range   | Off (0) or On (1) |
|                             | Access  | RW                |

If the host drive is defaulted (see the drive user guide for details), it will also clear the current configuration for the slot SI-DeviceNet is installed to.

This can be performed as follows:

- Set Pr **S.00.008** to On (1).
- Reset the module by setting Pr **S.00.007** to On (1).
- SI-DeviceNet communications will be stopped.
- Default parameter values for the SI-DeviceNet will be loaded.
- The SI-DeviceNet will reset using the default values.

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

## 6.3 Module menu 1 - DeviceNet Setup

Menu 1 contains all the parameters relating to the setup of the DeviceNet interface on the SI-DeviceNet module.

| Enable DeviceNet Interface |         |                   |
|----------------------------|---------|-------------------|
| <b>S.01.001</b>            | Default | On (1)            |
|                            | Range   | Off (0) or On (1) |
|                            | Access  | RO                |

This parameter displays a value of On (1) to indicate that the DeviceNet Interface has been enabled.

| Reset DeviceNet Interface |         |                   |
|---------------------------|---------|-------------------|
| <b>S.01.002</b>           | Default | Off (0)           |
|                           | Range   | Off (0) or On (1) |
|                           | Access  | RW                |

Changes to the SI-DeviceNet configuration will not take effect until the SI-DeviceNet has been reset.

To reset the SI-DeviceNet:

- Set Pr **S.01.002** to On (1).
- When the sequence has been completed, Pr **S.01.002** will be reset to Off (0).
- The SI-DeviceNet will reset using the updated configuration.

### NOTE

This sequence does NOT store the SI-DeviceNet configuration parameters in the drive or the SI-DeviceNet flash memory. This parameter will change back to Off immediately, and as such the change may not be visible in the display.

| Default DeviceNet Interface |         |                   |
|-----------------------------|---------|-------------------|
| <b>S.01.003</b>             | Default | Off (0)           |
|                             | Range   | Off (0) or On (1) |
|                             | Access  | RW                |

If the host drive is defaulted (see the drive user guide for details), it will also clear the current configuration for the slot SI-DeviceNet is installed to.

This can be performed as follows:

- Set Pr **S.01.003** to On (1).
- Reset the DeviceNet interface by setting Pr **S.01.002** to On (1).
- SI-DeviceNet communications will be stopped.
- Default parameter values for the DeviceNet interface will be loaded.
- The SI-DeviceNet will reset using the default values.

| DeviceNet node address |         |         |
|------------------------|---------|---------|
| <b>S.01.004</b>        | Default | 63      |
|                        | Range   | 0 to 63 |
|                        | Access  | RW      |

Every node on a DeviceNet network must be given a unique network node address. To activate a change in the node address value, the SI-DeviceNet must be reset (Pr **S.01.002** or **MM.007** = On (1)). Address number 63 is reserved for system use.

| Baud rate       |         |                                  |
|-----------------|---------|----------------------------------|
| <b>S.01.005</b> | Default | 125 kbps (0)                     |
|                 | Range   | Auto Detect (-1) to 500 kbps (2) |
|                 | Access  | RW                               |

The SI-DeviceNet will automatically detect the DeviceNet network data rate and synchronize to it. Pr **S.01.005** will indicate the data rate that has been detected by the SI-DeviceNet.

A value of -1 indicates that the SI-DeviceNet has not detected any activity on the DeviceNet network, and is waiting for the master controller to start communicating.

**NOTE**

The DeviceNet cyclic data rate parameter can be changed, but this will not affect the data rate at which the SI-DeviceNet communicates. The data rate display will be updated when the SI-DeviceNet is reset.

| Pr <b>S.01.005</b> | Bits/s         |
|--------------------|----------------|
| -1                 | Auto-detecting |
| 0                  | 125 k          |
| 1                  | 250 k          |
| 2                  | 500 k          |

| DeviceNet network diagnostic |         |        |
|------------------------------|---------|--------|
| <b>S.01.006</b>              | Default | N/A    |
|                              | Range   | 0 to 7 |
|                              | Access  | RO     |

| DeviceNet cyclic data rate |         |                      |
|----------------------------|---------|----------------------|
| <b>S.01.007</b>            | Default | N/A                  |
|                            | Range   | 0 to 9999 Messages/s |
|                            | Access  | RO                   |

The DeviceNet network activity can be monitored in the SI-DeviceNet operating status parameter, Pr **S.01.006**. When the SI-DeviceNet is in data exchange with the DeviceNet master controller, Pr **S.01.007** will give an indication of the number of cyclic data messages that are being processed per second.

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

All possible values of **S.01.006** are given in the table below.

| Value | Text           | Description  |
|-------|----------------|--|
| 0     | Network OK     | Network ok/healthy   |
| 1     | Init OK        | The SI-DeviceNet has initialized correctly and is waiting for the DeviceNet master to initialize communications.                             |
| 2     | No Cyclic      | No cyclic data has been recognized. This could be due to the length of the mapping data is not equal to the master setup.                    |
| 3     | Init Failed    | A part of the SI-DeviceNet initialization sequence was not successful. If this fault persists after a power-cycle, replace the SI-DeviceNet. |
| 4     | Comm Fault     | Fault found in the communications of the module. This could be due to different devices configured to use different baud rates.              |
| 5     | No 24 V        | No 24 V external PSU has been detected.  |
| 6     | Baud detecting | Automatic baud rate detection is in progress.  |
| 7     | Initializing   | The module is currently initializing.  |

| Network loss selection |         |              |
|------------------------|---------|--------------|
| <b>S.01.010</b>        | Default | 200 ms       |
|                        | Range   | 0 to 3000 ms |
|                        | Access  | RO           |

The network loss detection feature provides a method which ensures that communication with the master is still present. The SI-DeviceNet resets an internal timer when a valid message is received from the DeviceNet network, if a message is not received within the specified period, network loss is detected.

#### NOTE

Network loss detection is not enabled internally until cyclic data has been detected. This prevents spurious network loss timeouts while the DeviceNet master controller is initializing the DeviceNet network.

| Timeout action  |         |                           |
|-----------------|---------|---------------------------|
| <b>S.01.011</b> | Default | Trip (0)                  |
|                 | Range   | Trip (0) to No action (4) |
|                 | Access  | RW                        |

Pr **S.01.011** determines the action to take when a timeout specified by Pr **S.01.010** occurs. All possible actions and descriptions are listed below.

| Value | Text            | Description  |
|-------|-----------------|--|
| 0     | Trip            | Trip the drive                                     |
| 1     | Send fit values | Send fault values to output parameters             |
| 2     | Clear output    | PLC output parameters will have values set to zero |
| 3     | Hold last       | Hold the last value in the PLC output parameters   |
| 4     | No action       | No action with output parameters                   |

When a value of "Trip" is selected in Pr **S.01.011** and no cyclic communications have been detected in a time period defined by Pr **S.01.010** then the drive will trip displaying "SlotX Error" with a sub-trip string of "Link loss".

If the network loss timeout time (Pr **S.01.010**) is reduced too far, spurious network losses may occur due to a time-out occurring before the time period under normal operating conditions.



Network loss detection can be disabled by setting Pr **S.01.010** to 0. It is the user's responsibility to ensure that adequate safety precautions are taken to prevent damage or injury by disabling the drive in the event of a loss of communications.

If Pr **S.01.011** is set to "Send fit values", the fault values entered in Pr **S.04.001** to Pr **S.04.028** are sent to the mapped output parameters when a network timeout error occurs.

e.g. if Pr **S.03.001** = 20021 and Pr **S.03.002** = 20022 and a timeout error occurs, the value in Pr **S.04.001** will be sent to Pr **20.021** and the value in Pr **S.04.002** will be sent to Pr **20.022** as defined in the out mapping parameters.

If Pr **S.01.011** is set to "Clear output", all PLC output parameter values are set to zero.

e.g. if Pr **S.03.001** = 20021 and Pr **S.03.002** = 20022 and a timeout error occurs, Pr **20.021** and Pr **20.022** will be set to 0.

If Pr **S.01.011** is set to "Hold last", the last values sent by the PLC master are held in the mapped output parameters.

e.g. if Pr **S.03.001** = 20021 and Pr **S.03.002** = 20022 and a timeout error occurs, Pr **20.021** and Pr **20.022** will equal the last values sent by the PLC master.

If Pr **S.01.011** is set to "No action", then the module will not write any value to any mapped output parameters.

| Timeout Event Destination |         |                             |
|---------------------------|---------|-----------------------------|
| <b>S.01.012</b>           | Default | This Slot (0)               |
|                           | Range   | This Slot (0) to Slot 4 (4) |
|                           | Access  | RW                          |

| Timeout Event Type |         |                            |
|--------------------|---------|----------------------------|
| <b>S.01.013</b>    | Default | No Event (0)               |
|                    | Range   | No Event (0) to Event4 (4) |
|                    | Access  | RW                         |

When a timeout occurs, the SI-DeviceNet module can trigger an event defined by Pr **S.01.013** to a destination, such as an Option Module installed to a different slot on the drive, defined by Pr **S.01.012**.

**NOTE**

If triggering an event to a different Option Module, Pr **S.01.012** must point to a slot where a compatible Option Module is installed to.

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary/Of Terms       |
| Index                   |

| Cyclic data alignment |         |                       |
|-----------------------|---------|-----------------------|
| <b>S.01.014</b>       | Default | 32 (0)                |
|                       | Range   | 32 (0) or 16 (1) bits |
|                       | Access  | RW                    |

By default, the SI-DeviceNet uses 32 bits for each data channel, even if the target parameter in the drive is a 16-bit parameter. This strategy (known as casting), ensures that the cyclic data transmitted over the DeviceNet network remains aligned with the memory locations in 32-bit PLC's. When cyclic data alignment (Pr **S.01.014**) is set to "16 bits", a data channel will only use 32 bits if the target drive parameter is a 32-bit parameter. If the target drive parameter is only 1, 8 or 16 bits wide, 16 bits will be used for that particular data channel as shown in the following table.

| Parameter size (bits) | Actual data size (bits)<br>Alignment = 16 bits | Actual data size (bits)<br>Alignment = 32 bits |
|-----------------------|--|--|
| 1                     | 16   | 32   |
| 8                     |  |  |
| 16                    |  |  |
| 32                    | 32   |  |

The following examples demonstrate setting up a network using five cyclic channels for both IN and OUT data with the cyclic data alignment first set to 32 bits and then set to 16 bits.

Table 6.3 shows the mapping parameters where five IN and five OUT cyclic data channels are required. With data alignment set to 32 bits, each data channel uses 32 bits (two data words, so a total of ten words are required).

**Table 6.3 Mapping parameters**

| Data channel  | Data words used | Mapping for slot 3 | Setting  | Data width (bits) | Mapping status   |
|---------------|-----------------|--------------------|----------|-------------------|--|
| IN channel 1  | IN word 0, 1    | Pr <b>3.02.001</b> | 0.10.040 | 16                | Pr <b>10.040</b> , status word                         |
| IN channel 2  | IN word 2, 3    | Pr <b>3.02.002</b> | 0.02.001 | 32                | Pr <b>02.001</b> , post-ramp speed reference           |
| IN channel 3  | IN word 4, 5    | Pr <b>3.02.003</b> | 0.04.020 | 16                | Pr <b>04.020</b> , Motor load as % of rated motor load |
| IN channel 4  | IN word 6, 7    | Pr <b>3.02.004</b> | 0.14.021 | 16                | Pr <b>14.021</b> , PID1 feedback                       |
| IN channel 5  | IN word 8, 9    | Pr <b>3.02.005</b> | 0.14.001 | 16                | Pr <b>14.001</b> , PID1 output                         |
| OUT channel 1 | OUT word 0, 1   | Pr <b>3.03.001</b> | 0.06.042 | 16                | Pr <b>06.042</b> , control word                        |
| OUT channel 2 | OUT word 2, 3   | Pr <b>3.03.002</b> | 0.01.021 | 32                | Pr <b>01.021</b> , preset reference 1                  |
| OUT channel 3 | OUT word 4, 5   | Pr <b>3.03.003</b> | 0.02.011 | 32                | Pr <b>02.011</b> , acceleration rate 1                 |
| OUT channel 4 | OUT word 6, 7   | Pr <b>3.03.004</b> | 0.02.021 | 32                | Pr <b>02.021</b> , deceleration rate 1                 |
| OUT channel 5 | OUT word 8, 9   | Pr <b>3.03.005</b> | 0.14.020 | 16                | Pr <b>14.020</b> , PID1 reference                      |



It is advisable to keep 16-bit parameters paired together. This prevents mis-alignment of cyclic data with 32-bit PLC registers when using auto-mapping facilities to configure the DeviceNet network. By swapping the mappings for input channel 2 with input channel 3 and moving output channel 5 to output channel 2, the data channel structure will appear as shown in the following table.

| Data channel  | Data words used | Mapping for slot 3 | Setting  | Data width (bits) | Mapping status   |
|---------------|-----------------|--------------------|----------|-------------------|--|
| IN channel 1  | IN word 0       | Pr <b>3.02.001</b> | 0.10.040 | 16                | Pr <b>10.040</b> , status word                         |
| IN channel 2  | IN word 1       | Pr <b>3.02.002</b> | 0.04.020 | 16                | Pr <b>04.020</b> , Motor load as % of rated motor load |
| IN channel 3  | IN word 2, 3    | Pr <b>3.02.003</b> | 0.02.001 | 32                | Pr <b>02.001</b> , post-ramp speed reference           |
| IN channel 4  | IN word 4       | Pr <b>3.02.004</b> | 0.14.021 | 16                | Pr <b>14.021</b> , PID1 feedback                       |
| IN channel 5  | IN word 5       | Pr <b>3.02.005</b> | 0.14.001 | 16                | Pr <b>14.001</b> , PID1 output                         |
| OUT channel 1 | OUT word 0      | Pr <b>3.03.001</b> | 0.06.042 | 16                | Pr <b>06.042</b> , control word                        |
| OUT channel 2 | OUT word 1      | Pr <b>3.03.002</b> | 0.14.020 | 16                | Pr <b>14.020</b> , PID1 reference                      |
| OUT channel 3 | OUT word 2, 3   | Pr <b>3.03.003</b> | 0.01.021 | 32                | Pr <b>01.021</b> , preset reference 1                  |
| OUT channel 4 | OUT word 4, 5   | Pr <b>3.03.004</b> | 0.02.011 | 32                | Pr <b>02.011</b> , acceleration rate                   |
| OUT channel 5 | OUT word 6, 7   | Pr <b>3.03.005</b> | 0.02.021 | 32                | 1Pr <b>02.021</b> , deceleration rate 1                |

| Input cyclic assembly object ID |         |                       |
|---------------------------------|---------|-----------------------|
| <b>S.01.018</b>                 | Default | 112                   |
|                                 | Range   | 70-73, 106-160 (even) |
|                                 | Access  | RW                    |

| Output cyclic assembly object ID |         |                      |
|----------------------------------|---------|----------------------|
| <b>S.01.019</b>                  | Default | 113                  |
|                                  | Range   | 20-23, 107-161 (odd) |
|                                  | Access  | RW                   |

Pr **S.01.018** and **S.01.019** control the input and output DeviceNet objects and also the number of polled words that are to be sent and received.

Table 6.4 on page 34 shows the number of the polled words corresponding to Pr **S.01.018** and Pr **S.01.019**.

**Table 6.4 Polled words**

| <b>Polled words</b> | <b>Input assembly object<br/>(Pr S.01.018)</b> | <b>Output assembly object<br/>(Pr S.01.019)</b> |
|---------------------|--|---|
| 1                   | 106  | 107   |
| 2                   | 108  | 109   |
| 3                   | 110  | 111   |
| 4                   | 112  | 113   |
| 5                   | 114  | 115   |
| 6                   | 116  | 117   |
| 7                   | 118  | 119   |
| 8                   | 120  | 121   |
| 9                   | 122  | 123   |
| 10                  | 124  | 125   |
| 11                  | 126  | 127   |
| 12                  | 128  | 129   |
| 13                  | 130  | 131   |
| 14                  | 132  | 133   |
| 15                  | 134  | 135   |
| 16                  | 136  | 137   |
| 17                  | 138  | 139   |
| 18                  | 140  | 141   |
| 19                  | 142  | 143   |
| 20                  | 144  | 145   |
| 21                  | 146  | 147   |
| 22                  | 148  | 149   |
| 23                  | 150  | 151   |
| 24                  | 152  | 153   |
| 25                  | 154  | 155   |
| 26                  | 156  | 157   |
| 27                  | 158  | 159   |
| 28                  | 160  | 161   |

There are several assembly objects that are covered in the DeviceNet specification that are available for use. See the DeviceNet objects chapter.

| Input cyclic mapping length |         |         |
|-----------------------------|---------|---------|
| <b>S.01.020</b>             | Default | 4       |
|                             | Range   | 0 to 28 |
|                             | Access  | RO      |

| Output cyclic mapping length |         |         |
|------------------------------|---------|---------|
| <b>S.01.021</b>              | Default | 4       |
|                              | Range   | 0 to 28 |
|                              | Access  | RO      |

Pr **S.01.020** and Pr **S.01.021** indicate the current mapping length used for sending and receiving data.

To set a different value for the mapping lengths, refer to Pr **S.01.018** and Pr **S.01.019**.

| Input mapping status |         |                               |
|----------------------|---------|-------------------------------|
| <b>S.01.022</b>      | Default | N/A                           |
|                      | Range   | No error (0) to Reserved (10) |
|                      | Access  | RO                            |

| Output mapping status |         |                               |
|-----------------------|---------|-------------------------------|
| <b>S.01.023</b>       | Default | N/A                           |
|                       | Range   | No error (0) to Reserved (10) |
|                       | Access  | RO                            |

If the DeviceNet Network Diagnostic parameter (Pr **S.01.006**) indicates “Init Failed”, a mapping configuration error has been could have been detected. The reason for the error is indicated by the SI-DeviceNet input mapping status parameter (Pr **S.01.022**) and the SI-DeviceNet output mapping status parameter (Pr **S.01.023**).

When a mapping error has been corrected, reset the SI-DeviceNet module by setting Pr **S.01.002** or **MM.007** to On (1).

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

The mapping error codes are described in the table below:

| Value | Text             | Description  |
|-------|------------------|--|
| 0     | No error         | No error has been detected during mapping initialization.  |
| 1     | Par impossible   | The parameter may not exist or may not be readable.  |
| 2     | Hole in mapping  | Cyclic data mapping parameters are not contiguous.   |
| 3     | Dup mapping      | Two or more cyclic data mapping configuration parameters have been configured with the same destination parameter reference. |
| 4     | Length exceed    | The length of the mapped parameters exceeds the length of the selected assembly object.                                      |
| 5     | Obj not support  | The selected assembly object is not supported.   |
| 6     | Pre & uncompress | If the predefined object is selected, the data alignment must be set to 16 bits.   |
| 7     | Type unmatched   | The IN and OUT objects both must be predefined objects, or neither.  |
| 8     | Memory fault     | Failed to allocate memory for mapping.   |
| 9     | No mapping       | No parameter is assigned to the mapping.   |
| 10    | Reserved         | Reserved   |

| Input processing time |         |               |
|-----------------------|---------|---------------|
| <b>S.01.024</b>       | Default | N/A           |
|                       | Range   | 0 to 65535 ms |
|                       | Access  | RO            |

| Output processing time |         |               |
|------------------------|---------|---------------|
| <b>S.01.025</b>        | Default | N/A           |
|                        | Range   | 0 to 65535 ms |
|                        | Access  | RO            |

Pr **S.01.024** and Pr **S.01.025** display the input and output processing times respectively. The input processing time (Pr **S.01.024**) shows the time taken from the value being sent from the drive to the value being written to the master in milliseconds. The output processing time (Pr **S.01.025**) shows the time taken from the value being sent from the master to the value being successfully written to the drive in milliseconds.

| Input consistency enable |         |                   |
|--------------------------|---------|-------------------|
| <b>S.01.026</b>          | Default | Off (0)           |
|                          | Range   | Off (0) or On (1) |
|                          | Access  | RW                |

| Input consistency trigger parameter |         |                      |
|-------------------------------------|---------|----------------------|
| <b>S.01.027</b>                     | Default | N/A                  |
|                                     | Range   | 0.00.000 to 4.99.999 |
|                                     | Access  | RW                   |

| Output consistency enable |         |                   |
|---------------------------|---------|-------------------|
| <b>S.01.028</b>           | Default | Off (0)           |
|                           | Range   | Off (0) or On (1) |
|                           | Access  | RW                |

| Output consistency trigger parameter |         |                      |
|--------------------------------------|---------|----------------------|
| <b>S.01.029</b>                      | Default | N/A                  |
|                                      | Range   | 0.00.000 to 4.99.999 |
|                                      | Access  | RW                   |

The SI-DeviceNet module provides an input/output consistency feature which ensures that the data in the input or output mappings is only transferred between the SI-DeviceNet module and the master when the mapped parameters are ready. This prevents data skew between parameters in the input/output mappings.

If Input consistency action (Pr **S.01.026**) and Output consistency action (Pr **S.01.028**) are set to 0 (i.e. default settings), then the input/output consistency features are disabled so that input and output data is always read from or written to the master/module.

If Input Consistency Action (Pr **S.01.026**) is set to On (1), the SI-DeviceNet module will check the value of the parameter specified by the Input Consistency Trigger Source Parameter (Pr **S.01.027**). If the input trigger source parameter defined by Pr **S.01.027** is set to a non-zero value (for example by a user program in an applications module), this indicates to the SI-DeviceNet module that all the mapped parameters are ready to be read. The module will then read the mapped parameters, transfer them to the master and will then clear the input trigger source parameter to zero. When the input trigger source parameter is set to zero, the SI-DeviceNet module will continue to transfer the previously read data to the master.

If Output Consistency Action (Pr **S.01.028**) is set to On (1), the SI-DeviceNet module will check the value of the parameter specified by the Output Consistency Trigger Source Parameter (Pr **S.01.029**). The output trigger source parameter defined by Pr **S.01.029** will initially be set to 1.

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary/Of Terms       |
| Index                   |

If the output trigger source parameter is set to zero (for example by a user program in an applications module), this indicates to the SI-DeviceNet module that all the mapped parameters are ready to be written to. The module will then write the data from the master into the mapped parameters, and will then set the output trigger source parameter to 1. When the output trigger source parameter is set to 1, it indicates to the SI-DeviceNet module that the mapped parameters are not ready to be written to, and therefore any new data from the master will not be written to the mapped parameters in the drive until the output trigger source parameter is again set to zero.

| Custom product type |         |                                   |
|---------------------|---------|-----------------------------------|
| <b>S.01.031</b>     | Default | Unidrive M (0)                    |
|                     | Range   | Unidrive M (0) or Unidrive SP (1) |
|                     | Access  | RW                                |

A backwards compatibility mode is present in SI-DeviceNet. Pr **S.01.031** can be used to allow the SI-DeviceNet module to appear as an SM-DeviceNet module, this only applies to the network and not the control/status words and parameter sizes. The module must be configured to match the existing network settings of the drive it is replacing (including any parameter mappings).

Using the compatibility mode allows the replacement of drives on a DeviceNet network, without having to make any changes to the master network configuration, it changes the identity code of the module so that the master believes that a similar type drive is present for a particular node.

| Custom product version |         |           |
|------------------------|---------|-----------|
| <b>S.01.032</b>        | Default | 0         |
|                        | Range   | 0 to 9999 |
|                        | Access  | RW        |

When compatibility mode has been enabled, Pr **S.01.032** should contain the correct product code to respond to the DeviceNet master. This product code should match the product code that is being used in the appropriate EDS files.

**NOTE**

When using compatibility mode, ensure that the correct EDS file for the simulated drive is being used and not the actual drive.



This mode only changes the network to emulate the Unidrive SP on the network. Changes to the control method and data size differences must still be considered. This mode does NOT allow direct replacement.

| Bus Off trip    |         |                           |
|-----------------|---------|---------------------------|
| <b>S.01.034</b> | Default | Enable (0)                |
|                 | Range   | Enable (0) or Disable (1) |
|                 | Access  | RW                        |

The CAN hardware layer used by DeviceNet has a built-in safety mechanism where nodes experiencing regular problem with receiving or transmitting CAN frames will go off line. In this case, the SI-DeviceNet will trip the drive and it will not be possible to communicate with the drive via DeviceNet until the SI-DeviceNet has been reset.

Bus Off errors will generally only occur if the DeviceNet network is broken, the wiring becomes faulty or there is noise on the network. However, in some applications, such as a continuous casting process, there is a requirement for the drive to continue to run in the event of a major network failure.

When Pr **S.01.034** is set to Disable (1), the BUS Off condition may still be entered, but the SI-DeviceNet does not trip the drive. Some external provision must be made to disable the drive when the process has reached a point at which it is safe to stop.

| Motor 1 type    |         |   |
|-----------------|---------|---|
| <b>S.01.040</b> | Default | FC DC Motor (2)                                 |
|                 | Range   | FC DC Motor (2) to Trapezoidal PM BL Motor (10) |
|                 | Access  | RO  |

| Motor 2 type    |         |   |
|-----------------|---------|---|
| <b>S.01.041</b> | Default | FC DC Motor (2)                                 |
|                 | Range   | FC DC Motor (2) to Trapezoidal PM BL Motor (10) |
|                 | Access  | RO  |

There are 2 instances of the Motor Data object. Instance 1 will represent the Menu 5 motor information (Motor Map 1) and instance 2 will represent the menu 21 motor map. (Motor Map 2) The instance being used by the other dependant DeviceNet objects will be determined by Pr **21.015**. Pr **21.015** is polled in the background task, so the user should be aware that during motor map changeover, the rpm speed reference might not be accurate.

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

## 6.4 Module menu 2 - Input Mappings

Menu 2 contains all the mapping parameters relating to the IN channels of the module.

The values set in each parameter are in the format of **S.mm.ppp** where:

**S** = slot number of the target/source parameter

**mm** = menu number of the target /source parameter

**ppp** = parameter number of the target/source parameter

| IN channel | Mapping parameter  | Default value |
|------------|--------------------|---------------|
| 1          | Pr <b>S.02.001</b> | 0.10.040      |
| 2          | Pr <b>S.02.002</b> | 0.02.001      |
| 3          | Pr <b>S.02.003</b> | 0.00.000      |
| 4          | Pr <b>S.02.004</b> | 0.00.000      |
| 5          | Pr <b>S.02.005</b> | 0.00.000      |
| 6          | Pr <b>S.02.006</b> | 0.00.000      |
| 7          | Pr <b>S.02.007</b> | 0.00.000      |
| 8          | Pr <b>S.02.008</b> | 0.00.000      |
| 9          | Pr <b>S.02.009</b> | 0.00.000      |
| 10         | Pr <b>S.02.010</b> | 0.00.000      |
| 11         | Pr <b>S.02.011</b> | 0.00.000      |
| 12         | Pr <b>S.02.012</b> | 0.00.000      |
| 13         | Pr <b>S.02.013</b> | 0.00.000      |
| 14         | Pr <b>S.02.014</b> | 0.00.000      |
| 15         | Pr <b>S.02.015</b> | 0.00.000      |
| 16         | Pr <b>S.02.016</b> | 0.00.000      |
| 17         | Pr <b>S.02.017</b> | 0.00.000      |
| 18         | Pr <b>S.02.018</b> | 0.00.000      |
| 19         | Pr <b>S.02.019</b> | 0.00.000      |
| 20         | Pr <b>S.02.020</b> | 0.00.000      |
| 21         | Pr <b>S.02.021</b> | 0.00.000      |
| 22         | Pr <b>S.02.022</b> | 0.00.000      |
| 23         | Pr <b>S.02.023</b> | 0.00.000      |
| 24         | Pr <b>S.02.024</b> | 0.00.000      |
| 25         | Pr <b>S.02.025</b> | 0.00.000      |
| 26         | Pr <b>S.02.026</b> | 0.00.000      |
| 27         | Pr <b>S.02.027</b> | 0.00.000      |
| 28         | Pr <b>S.02.028</b> | 0.00.000      |



## 6.5 Module menu 3 - Output Mappings

Menu 3 contains all the mapping parameters relating to the OUT channels of the module.

The values set in each parameter are in the format of **S.mm.ppp** where:

**S** = slot number of the target/source parameter

**mm** = menu number of the target /source parameter

**ppp** = parameter number of the target/source parameter

| OUT channel | Mapping parameter  | Default value |
|-------------|--------------------|---------------|
| 1           | Pr <b>S.03.001</b> | 0.06.042      |
| 2           | Pr <b>S.03.002</b> | 0.01.021      |
| 3           | Pr <b>S.03.003</b> | 0.00.000      |
| 4           | Pr <b>S.03.004</b> | 0.00.000      |
| 5           | Pr <b>S.03.005</b> | 0.00.000      |
| 6           | Pr <b>S.03.006</b> | 0.00.000      |
| 7           | Pr <b>S.03.007</b> | 0.00.000      |
| 8           | Pr <b>S.03.008</b> | 0.00.000      |
| 9           | Pr <b>S.03.009</b> | 0.00.000      |
| 10          | Pr <b>S.03.010</b> | 0.00.000      |
| 11          | Pr <b>S.03.011</b> | 0.00.000      |
| 12          | Pr <b>S.03.012</b> | 0.00.000      |
| 13          | Pr <b>S.03.013</b> | 0.00.000      |
| 14          | Pr <b>S.03.014</b> | 0.00.000      |
| 15          | Pr <b>S.03.015</b> | 0.00.000      |
| 16          | Pr <b>S.03.016</b> | 0.00.000      |
| 17          | Pr <b>S.03.017</b> | 0.00.000      |
| 18          | Pr <b>S.03.018</b> | 0.00.000      |
| 19          | Pr <b>S.03.019</b> | 0.00.000      |
| 20          | Pr <b>S.03.020</b> | 0.00.000      |
| 21          | Pr <b>S.03.021</b> | 0.00.000      |
| 22          | Pr <b>S.03.022</b> | 0.00.000      |
| 23          | Pr <b>S.03.023</b> | 0.00.000      |
| 24          | Pr <b>S.03.024</b> | 0.00.000      |
| 25          | Pr <b>S.03.025</b> | 0.00.000      |
| 26          | Pr <b>S.03.026</b> | 0.00.000      |
| 27          | Pr <b>S.03.027</b> | 0.00.000      |
| 28          | Pr <b>S.03.028</b> | 0.00.000      |

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

## 6.6 Module menu 4 - Fault Values

Menu 4 contains all the fault values that are sent to the mapped output destination parameters when fault values have been configured to be sent using an action parameter.

| OUT channel | Parameter          |
|-------------|--------------------|
| 1           | Pr <b>S.04.001</b> |
| 2           | Pr <b>S.04.002</b> |
| 3           | Pr <b>S.04.003</b> |
| 4           | Pr <b>S.04.004</b> |
| 5           | Pr <b>S.04.005</b> |
| 6           | Pr <b>S.04.006</b> |
| 7           | Pr <b>S.04.007</b> |
| 8           | Pr <b>S.04.008</b> |
| 9           | Pr <b>S.04.009</b> |
| 10          | Pr <b>S.04.010</b> |
| 11          | Pr <b>S.04.011</b> |
| 12          | Pr <b>S.04.012</b> |
| 13          | Pr <b>S.04.013</b> |
| 14          | Pr <b>S.04.014</b> |
| 15          | Pr <b>S.04.015</b> |
| 16          | Pr <b>S.04.016</b> |
| 17          | Pr <b>S.04.017</b> |
| 18          | Pr <b>S.04.018</b> |
| 19          | Pr <b>S.04.019</b> |
| 20          | Pr <b>S.04.020</b> |
| 21          | Pr <b>S.04.021</b> |
| 22          | Pr <b>S.04.022</b> |
| 23          | Pr <b>S.04.023</b> |
| 24          | Pr <b>S.04.024</b> |
| 25          | Pr <b>S.04.025</b> |
| 26          | Pr <b>S.04.026</b> |
| 27          | Pr <b>S.04.027</b> |
| 28          | Pr <b>S.04.028</b> |

## Module menu 9 - Resources

| PCB temperature 1 |         |               |
|-------------------|---------|---------------|
| <b>S.09.030</b>   | Default | N/A           |
|                   | Range   | -128 to 127°C |
|                   | Access  | RO            |

| PCB temperature 2 |         |               |
|-------------------|---------|---------------|
| <b>S.09.031</b>   | Default | N/A           |
|                   | Range   | -128 to 127°C |
|                   | Access  | RO            |

Parameters **S.09.030** and **S.09.031** display the current temperature of the 2 internal thermistors within the option module.

|                         |
|-------------------------|
| Parameters              |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| <b>Parameters</b>       |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

---

# 7 Non cyclic data

---

## 7.1 Introduction

“Explicit data” is the non cyclic data channel on DeviceNet that provides access to any parameter and DeviceNet object within SI-DeviceNet. As such, it is always enabled and active on SI-DeviceNet. Object access using explicit data is controlled entirely by the master controller program, and is not usually configured in any way when the DeviceNet network mapping is defined.

**NOTE** As non-cyclic data control is implemented entirely in the DeviceNet master controller, the method used will depend entirely on the type of master controller used.

## 7.2 Explicit parameter access

The Control Techniques object (Class 100 or 0x64) provides access to all drive parameters, using the parameters as shown:

|             |            |                      |
|-------------|------------|----------------------|
| Class code: | 100 (0x64) |                      |
| Instance:   | Menu       |                      |
| Attribute:  | Parameter  |                      |
| Read Code:  | 14 (0x0E)  | Get_Attribute_Single |
| Write Code: | 16 (0x10)  | Set_Attribute_Single |

All supported pre-defined DeviceNet objects can also be accessed using explicit messaging. Refer to the master controller documentation for full details about explicit messaging, and how to implement explicit messaging within the particular master controller.

**NOTE** Menu 0 parameters in the drive can be access using instance 200 (0xC8).

When accessing drive parameters using the Control Techniques object, all parameters must be treated as signed 32-bit parameters.

**NOTE** Multiple parameter access (using the Get\_Attribute\_All service) is not supported by SI-DeviceNet.

# 8 Control / status word

## 8.1 What are control and status words?

The control and status words allow the digital control and monitoring of the drive to be implemented using a single data word for each function. Each bit in the control word has a particular function and provides a method of controlling the output functions of the drive, such as run and direction. These words can be accessed using either cyclic or non-cyclic data.

Each bit in the status word provides feedback about the drives state of health and operational condition, such as drive OK, drive at speed, etc.

## 8.2 Control word

The SI-DeviceNet control word consists of 16 control bits some of which are reserved. See Table 8.1 for the individual bit function descriptions.

**Table 8.1 Control word bit definitions**

| b15  | b14            | b13   | b12        | b11        | b10        | b9         | b8     |
|------|----------------|-------|------------|------------|------------|------------|--------|
|      | KEYPAD<br>WDOG | RESET | TRIP       |            |            | JOG<br>REV | REMOTE |
| b7   | b6             | b5    | b4         | b3         | b2         | b1         | b0     |
| AUTO | NOT<br>STOP    | RUN   | FWD<br>REV | RUN<br>REV | JOG<br>FWD | RUN<br>FWD | ENABLE |

To enable fieldbus control the fieldbus enable signal (Pr **06.043**) and the auto bit (bit7) must both be set to '1'. When the AUTO bit is reset to 0 the drive will revert to terminal control.

For safety reasons, the external HARDWARE ENABLE signal must be present before the fieldbus control word can be used to start the drive. This terminal is normally controlled by an external "Emergency Stop" circuit to ensure that the drive is disabled in an emergency situation.

The control word REMOTE bit directly controls the drive parameter Pr **01.042**, the function of which is to select the digital speed reference as the source of the drives speed reference. When the REMOTE bit is reset to 0 the drive will revert to using the external analog speed reference.

The actual digital speed reference selected when REMOTE is set to 1 will be Pr **01.021**, which is also the default mapping for the fieldbus speed reference. However Pr **01.015** can be used to change which of the digital references is selected. For further details on the drive digital speed references, please refer to the appropriate drive *User Guide*.

Table 8.2 lists in detail the function of each control word bit. For further in-depth details about drive control words and sequencing bits please refer to the appropriate drive *User Guides*.

**NOTE**

When a trip occurs, the drive control word MUST be set to a safe, disabled state. This ensures that the drive does not re-start unexpectedly when it is reset. This can be achieved by continuously monitoring the drive status word and interlocking it with the control word.

|                              |
|------------------------------|
| Safety Information           |
| Introduction                 |
| Mechanical Installation      |
| Electrical Installation      |
| Getting started              |
| Parameters                   |
| Non cyclic data              |
| <b>Control / status word</b> |
| EDS Files                    |
| Advanced Features            |
| DeviceNet Objects            |
| Diagnostics                  |
| Glossary/Of Terms            |
| Index                        |

**NOTE**

By default data compression is off and therefore the control word will be cast as 32 bit with bits 16-31 reserved.

**Table 8.2 Control word bit functions**

| Bit | Function    | Description   |
|-----|-------------|---|
| 0   | ENABLE      | Set to 1 to enable the drive. Resetting to 0 will immediately disable the drive, and the motor will <b>coast</b> to a stop. The external HARDWARE ENABLE signal must also be present before the drive can be enabled.   |
| 1   | RUN FWD     | Set to 1 (with ENABLE set to 1) to run the motor in the forward direction. When reset to 0, the drive will <b>decelerate</b> the motor to a controlled stop.  |
| 2   | JOG FWD     | Set to 1 to jog the motor forward. This signal needs to be used in conjunction with the ENABLE bit. This signal is overridden by a RUN, RUN REV or RUN FWD signal.  |
| 3   | RUN REV     | Set to 1 (with ENABLE set to 1) to run the motor in the reverse direction. When reset to 0, the drive will <b>decelerate</b> the motor to a controlled stop.  |
| 4   | FWD REV     | Set to 1 to select the reverse direction. Set to 0 to run in the forward direction. The RUN signal is used to start and stop the motor.   |
| 5   | RUN         | Set to 1 to run the motor. FWD REV is used to select the direction of motor rotation. When reset to 0, the drive will <b>decelerate</b> the motor to a controlled stop.   |
| 6   | NOT STOP    | Set to 1 to allow the sequencing bit in the drive to be latched. Refer to the drive <i>Advanced User Guide</i> for more details. If NOT STOP is zero, all latches are cleared and held at 0. Pr <b>06.004</b> must be correctly set for this to function.   |
| 7   | AUTO        | Set to 1 to enable fieldbus control of the drive Control Word. The Control Word Enable (Pr <b>06.043</b> ) must also be set to 1. When reset to 0, the drive will operate under terminal control.   |
| 8   | REMOTE      | Set to 1 to select digital speed reference 1 (Pr <b>01.021</b> ), and to 0 to select analog reference 1 (Pr <b>01.036</b> ). REMOTE directly controls Pr <b>01.042</b> , so reference selector (Pr <b>01.014</b> ) and preset selector (Pr <b>01.015</b> ) must both be set to 0 (default) for the REMOTE bit to work properly.   |
| 9   | JOG REV     | Set to 1 to jog the motor in reverse. This signal needs to be used in conjunction with the ENABLE bit. This signal is overridden by a RUN/RUN REV/RUN FWD command.  |
| 10  | Reserved    |   |
| 11  | Reserved    |   |
| 12  | TRIP        | Set to 1 to trip the drive at any time. The trip display on the drive will be "Control Word" and the trip code will be 35. AUTO (b7) has no effect on this function. The trip cannot be cleared until TRIP is reset to 0.   |
| 13  | RESET       | A 0-1 transition of the RESET bit will reset the drive from a trip condition. If the reason for the trip is still present, or another fault condition has been detected, the drive will immediately trip again. When resetting the drive, it is recommended to check the status word to ensure that the reset was successful, before attempting to re-start the drive.  |
| 14  | KEYPAD WDOG | This watchdog is provided for an external keypad or other devices where a break in the communication link must be detected. The watchdog system can be enabled and/or serviced if this bit is changed from zero to one while the control word enabled. Once the watchdog is enabled it must be serviced at least once every second or an "Watchdog" trip will occur. The watchdog is disabled when a "Watchdog" trip occurs, and so it must be re-enabled when the trip is reset. |
| 15  | Reserved    |   |

## 8.3 Status word

The SI-DeviceNet status word consists of 16 control bits some of which are reserved. See the table below for the individual bit function descriptions.

|                    |                 |                           |                             |                                   |                     |              |                      |
|--------------------|-----------------|---------------------------|-----------------------------|-----------------------------------|---------------------|--------------|----------------------|
| <b>b15</b>         | <b>b14</b>      | <b>b13</b>                | <b>b12</b>                  | <b>b11</b>                        | <b>b10</b>          | <b>b9</b>    | <b>b8</b>            |
| Not Used           | Supply Loss     | Reverse Direction Running | Reverse Direction Commanded | Brake Resistor Alarm              | Braking IGBT Active | Regenerating | Current Limit Active |
| <b>b7</b>          | <b>b6</b>       | <b>b5</b>                 | <b>b4</b>                   | <b>b3</b>                         | <b>b2</b>           | <b>b1</b>    | <b>b0</b>            |
| Rated Load Reached | Above Set Speed | At Set Speed              | Below Set Speed             | Running At or Below Minimum Speed | Zero Speed          | Drive Active | Drive OK/ Healthy    |

The fieldbus status word is mapped directly from the drive status word, Pr **10.040**.

Pr **10.040**, is generated by the values of several individual drive status bits. Table 7.3 *Mapping for 2 polled channels* on page 40 shows the function indicated by each bit in the status word when set to 1.

**Table 8.3 Drive status word bit functions**

| Bit | Parameter        | Description   |
|-----|------------------|---|
| 0   | Pr <b>10.001</b> | bit 0 = 0:<br>Drive not ok (tripped).<br>bit 0 = 1:<br>Drive ok.  |
| 1   | Pr <b>10.002</b> | <b>Drive active</b><br>When bit 1 = 1, the drive is in run mode.  |
| 2   | Pr <b>10.003</b> | <b>Zero speed</b><br>In Open Loop mode, zero speed indicates that the absolute value of the post-ramp speed reference is at or below the zero speed threshold.<br>In RFC-A and RFC-5 modes, zero speed indicates that the absolute value of speed feedback is at or below the zero speed threshold.   |
| 3   | Pr <b>10.004</b> | <b>Running at or below minimum speed</b><br>In bipolar mode (Pr <b>01.010</b> = 1) Pr <b>10.004</b> is the same as zero speed, Pr <b>10.003</b> (See above).<br>In unipolar mode, Pr <b>10.004</b> is set if the absolute value of the post-ramp speed reference (Pr <b>02.001</b> ) or speed feedback (Pr <b>03.002</b> ) is at or below minimum speed + 0.5Hz or 5 rpm (Minimum speed is defined by Pr <b>01.007</b> ). This parameter is only set if the drive is running. |
| 4   | Pr <b>10.005</b> | <b>Below set speed</b><br>Only set if the drive is running at below set speed. Refer to Pr <b>03.006</b> , Pr <b>03.007</b> and Pr <b>03.009</b> in the drive documentation for more details.   |
| 5   | Pr <b>10.006</b> | <b>At speed</b><br>Only set if the drive is running at set speed.<br>Refer to Pr <b>03.006</b> , Pr <b>03.007</b> and Pr <b>03.009</b> in the drive documentation.  |

| Bit | Parameter  | Description  |
|-----|------------|--|
| 6   | Pr 10.007  | <b>Above set speed</b><br>Only set if the drive is running at above set speed. Refer to Pr 03.006, Pr 03.007 and Pr 03.009 in the drive documentation for more details.  |
| 7   | Pr 10.008  | <b>Load reached</b><br>Indicates that the modulus of the active current is greater or equal to the rated active current, as defined in menu 4. Refer to the drive documentation for more details.  |
| 8   | Pr 10.009  | <b>In current limit</b><br>Indicates that the current limits are active.   |
| 9   | Pr 10.010  | <b>Regenerating</b><br>Indicates that power is being transferred from the motor to the drive.<br>Regen mode: Indicates that power is being transferred from the drive to the supply.   |
| 10  | Pr 10.011  | <b>Dynamic brake active</b><br>Indicates that the braking IGBT is active. If the IGBT becomes active, this parameter will remain on for at least one second.   |
| 11  | Pr 10.012  | <b>Dynamic brake alarm</b><br>Dynamic brake alarm is set when the braking IGBT is active, and the braking energy accumulator is greater than 75 %.   |
| 12  | Pr 10.013  | <b>Reverse direction commanded</b><br>Direction commanded is set to 1 if the Pre-ramp speed reference (Pr 01.003) is negative and reset to 0 if the Pre-ramp speed reference is zero or positive.  |
| 13  | Pr 10.014  | <b>Reverse direction running</b><br>A 0 indicates forward direction and a 1 indicates reverse direction. The source of this bit is Pr 02.001 for open loop mode and Pr 03.002 for RFC-A and RFC-S modes.   |
| 14  | Pr 10.015  | <b>Supply loss</b><br>Supply loss indicates that the drive has detected a supply loss from the level of the DC bus voltage. This parameter can only become active if supply loss ride through or supply loss stop modes are selected.<br>In regen mode, supply loss is the inverse of Pr 03.007. |
| 15  | (Not Used) | <b>Reserved</b>  |



---

# 9 EDS Files

---

## 9.1 What are EDS files?

EDS (Electronic Data Sheets) files are text files that are used by SI-DeviceNet network configuration software tools. They contain information about the device, such as manufacturer, product type, product code, etc., and they also provide information on the default settings and functions supported by the device. Mapping information is also included that allows access to device parameters over the SI-DeviceNet network.

EDS files are not downloaded to the PLC or scanner, and are only used during network configuration. It is actually possible to configure a network without the EDS files.

## 9.2 Generic EDS files

Generic EDS files are available for all supported drives. These files are available from your local Control Techniques Drive Centre or supplier.

Drive icon files are also supplied for use with the SI-DeviceNet configuration software being used. EDS files must usually be installed into the software package being used to configure a SI-DeviceNet network. Refer to the software documentation supplied with the master for instructions on how to install EDS files. Control Techniques cannot provide specific technical support for any of these software packages.

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| <b>EDS Files</b>        |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary/Of Terms       |
| Index                   |

---

# 10 Advanced Features

---

## 10.1 Supported Drive assembly objects

The DeviceNet specification includes a series of pre-defined assembly objects for different devices, including Drives, and the SI-DeviceNet supports several of these pre-defined assembly objects. The format of the DeviceNet pre-defined assembly objects is fixed.

**Table 10.1 Pre-defined SI-DeviceNet assembly objects**

| Object    | Type   | Object name                              |
|-----------|--------|--|
| 20 (0x14) | Output | Basic speed control output               |
| 21 (0x15) | Output | Extended speed control output            |
| 22 (0x16) | Output | Speed and torque control output          |
| 23 (0x17) | Output | Extended speed and torque control output |
| 70 (0x46) | Input  | Basic speed feedback                     |
| 71 (0x47) | Input  | Extended speed feedback                  |
| 72 (0x48) | Input  | Basic speed and torque feedback          |
| 73 (0x49) | Input  | Extended speed and torque feedback       |

To select a pre-defined input or output assembly object:

1. Specify the input assembly object required in Pr **S.01.018**.
2. Specify the output assembly object required in Pr **S.01.019**.
3. Set Pr **MM.007** to On to reset the SI-DeviceNet, and make the changes take effect.

**NOTE**

The parameter mapping of the pre-defined DeviceNet objects CANNOT be changed.

### 10.1.1 Basic speed control

#### Output assembly object 20

The scanner must be configured for 4 Tx bytes (or 2 Tx words) if this output assembly object is selected.

**Table 10.2 Basic speed control**

| Data word | Function                       |
|-----------|--------------------------------|
| Word 0    | Basic control word (See below) |
| Word 1    | SpeedRef (See status word)     |

The basic control word uses a full 16-bit word, with the bits having functions as shown below.

|     |     |     |     |     |          |    |        |
|-----|-----|-----|-----|-----|----------|----|--------|
| b15 | b14 | b13 | b12 | b11 | b10      | b9 | b8     |
|     |     |     |     |     |          |    |        |
| b7  | b6  | b5  | b4  | b3  | b2       | b1 | b0     |
|     |     |     |     |     | FaultRst |    | RunFwd |

## 10.1.2 Extended speed control

### Output assembly object 21

The scanner must be configured for 4 Tx bytes (or 2 Tx words) if this output assembly object is selected.

**Table 10.3 Extended speed control**

| Data word | Function                           |
|-----------|------------------------------------|
| Word 0    | Extended control word (see below). |
| Word 1    | SpeedRef (see status word).        |

The extended control word uses a full 16-bit word, with the bits having functions as shown below.

| b15 | b14    | b13     | b12 | b11 | b10      | b9     | b8     |
|-----|--------|---------|-----|-----|----------|--------|--------|
|     |        |         |     |     |          |        |        |
| b7  | b6     | b5      | b4  | b3  | b2       | b1     | b0     |
|     | NetRef | NetCtrl |     |     | FaultRst | RunRev | RunFwd |

## 10.1.3 Basic speed and torque control

### Output assembly object 22

The scanner must be configured for 6 Tx bytes (or 3 Tx words) if this output assembly object is selected.

**Table 10.4 Basic speed and torque control**

| Data Word | Function                       |
|-----------|--------------------------------|
| Word 0    | Basic control word (See below) |
| Word 1    | SpeedRef (See status word)     |
| Word 2    | TorqueRef (See status word)    |

The basic control word uses a full 16-bit word, with the bits having functions as shown below.

| b15 | b14 | b13 | b12 | b11 | b10      | b9 | b8     |
|-----|-----|-----|-----|-----|----------|----|--------|
|     |     |     |     |     |          |    |        |
| b7  | b6  | b5  | b4  | b3  | b2       | b1 | b0     |
|     |     |     |     |     | FaultRst |    | RunFwd |

## 10.1.4 Extended speed and torque control

### Output assembly object 23

The scanner must be configured for 6 Tx bytes (or 3 Tx words) if this output assembly object is selected.

**Table 10.5 Extended speed and torque control**

| Data word | Function                          |
|-----------|-----------------------------------|
| Word 0    | Extended control word (See below) |
| Word 1    | SpeedRef (See status word)        |
| Word 2    | TorqueRef (See status word)       |

The extended control word uses a full 16-bit word, with the bits having functions as shown below.

|     |        |         |     |     |          |        |        |
|-----|--------|---------|-----|-----|----------|--------|--------|
| b15 | b14    | b13     | b12 | b11 | b10      | b9     | b8     |
|     |        |         |     |     |          |        |        |
| b7  | b6     | b5      | b4  | b3  | b2       | b1     | b0     |
|     | NetRef | NetCtrl |     |     | FaultRst | RunRev | RunFwd |

### 10.1.5 Basic speed feedback

#### Input assembly object 70

The scanner must be configured for 4 Rx bytes (or 2 Rx words) if this input assembly object is selected.

**Table 10.6 Basic speed feedback**

| Data word | Function                      |
|-----------|-------------------------------|
| Word 0    | Basic status word (See below) |
| Word 1    | SpeedActual (See status word) |

The basic status word uses a full 16-bit word, with the bits having functions as shown below.

|     |     |     |     |     |          |    |         |
|-----|-----|-----|-----|-----|----------|----|---------|
| b15 | b14 | b13 | b12 | b11 | b10      | b9 | b8      |
|     |     |     |     |     |          |    |         |
| b7  | b6  | b5  | b4  | b3  | b2       | b1 | b0      |
|     |     |     |     |     | Running1 |    | Faulted |

### 10.1.6 Extended speed feedback

#### Input assembly object 71

The scanner must be configured for 4 Rx bytes (or 2 Rx words) if this input assembly object is selected.

**Table 10.7 Extended speed feedback**

| Data word | Function                      |
|-----------|-------------------------------|
| Word 0    | Basic status word (see below) |
| Word 1    | SpeedActual (see status word) |

The basic status word uses a full 16-bit word, with the bits having functions as shown below.

|              |             |              |       |          |          |         |         |
|--------------|-------------|--------------|-------|----------|----------|---------|---------|
| b15          | b14         | b13          | b12   | b11      | b10      | b9      | b8      |
| DriveState   |             |              |       |          |          |         |         |
| b7           | b6          | b5           | b4    | b3       | b2       | b1      | b0      |
| At Reference | RefFrom Net | CtrlFrom Net | Ready | Running2 | Running1 | Warning | Faulted |

## 10.1.7 Basic speed and torque feedback

### Input assembly object 72

The scanner must be configured for 6 Rx bytes (or 3 Rx words) if this input assembly object is selected'.

**Table 10.8 Basic speed and torque feedback**

| Data word | Function                       |
|-----------|--------------------------------|
| Word 0    | Basic status word (see below)  |
| Word 1    | SpeedActual (see status word)  |
| Word 2    | TorqueActual (see status word) |

The extended status word uses a full 16-bit word, with the bits having functions as shown below.

| b15 | b14 | b13 | b12 | b11 | b10      | b9 | b8      |
|-----|-----|-----|-----|-----|----------|----|---------|
|     |     |     |     |     |          |    |         |
| b7  | b6  | b5  | b4  | b3  | b2       | b1 | b0      |
|     |     |     |     |     | Running1 |    | Faulted |

## 10.1.8 Extended speed and torque feedback

### Input assembly object 73

The scanner must be configured for 6 Rx bytes (or 3 Rx words) if this input assembly object is selected.

**Table 10.9 Extended speed and torque feedback**

| Data word | Function                       |
|-----------|--------------------------------|
| Word 0    | Basic status word (See below)  |
| Word 1    | SpeedActual (See status word)  |
| Word 2    | TorqueActual (See status word) |

The extended status word uses a full 16-bit word, with the bits having functions as shown below.

| b15          | b14         | b13          | b12   | b11      | b10      | b9      | b8      |
|--------------|-------------|--------------|-------|----------|----------|---------|---------|
| DriveState   |             |              |       |          |          |         |         |
| b7           | b6          | b5           | b4    | b3       | b2       | b1      | b0      |
| At Reference | RefFrom Net | CtrlFrom Net | Ready | Running2 | Running1 | Warning | Faulted |

# 11 DeviceNet Objects

The Object Model has the following object classes present.

**Table 11.1 Supported Objects**

| Object Class       | Class Code                    | No. of instances | Effect on behaviour  |
|--------------------|-------------------------------|------------------|--|
| Identity           | 1 (0x01)                      | 1                | Supports the device reset service  |
| Message Router     | 2 (0x02)                      |                  | Internally routes messages   |
| DeviceNet          | 3 (0x03)                      |                  | Configures device attributes   |
| Assembly           | 4 (0x04)                      | 64               | Defines I/O data format, i.e parameter mapping   |
| Connection         | 5 (0x05)                      | 2                | Logic ports into or out of the drive   |
| Motor Data         | 40 (0x28)                     | 2                | Defines the motor data   |
| Control Supervisor | 41 (0x29)                     | 1                | Manages drive functions, operational states and control  |
| AC/DC Drive        | 42 (0x2A)                     |                  | Provides drive configuration   |
| CT Group           | 100 (0x64)                    | <No. of menus>   | Provides an interface to all drive parameters<br>Be aware that menu 200 is used to access menu 0(Setup menu)           |
| CT Local slot      | 101 (0x65)                    |                  | Provides a shortcut to access the local slot parameters<br>Be aware that menu 200 is used to access menu 0(Setup menu) |
| CT Slot 1-4        | 102 (0x66)<br>-<br>105 (0x69) |                  | Provides an interface to option slot 1-4 parameters<br>Be aware that menu 200 is used to access menu 0(Setup menu)     |

## 11.1 Identity Object

**Class: 0x01 (1)**

This object provides identification of and general information about the device.

### 11.1.1 VendorID

|                  |          |                  |      |
|------------------|----------|------------------|------|
| <b>Name:</b>     | VendorID |                  |      |
| <b>Class</b>     | 0x01     | <b>Default</b>   | 257  |
| <b>Instance</b>  | 0x01     | <b>Data Type</b> | UINT |
| <b>Attribute</b> | 0x01     | <b>Access</b>    | Get  |

Returns the Vendor ID code, which is 0x101 (257) for Control Techniques.

### 11.1.2 DeviceType

|                  |            |                  |      |
|------------------|------------|------------------|------|
| <b>Name:</b>     | DeviceType |                  |      |
| <b>Class</b>     | 0x01       | <b>Default</b>   | 2    |
| <b>Instance</b>  | 0x01       | <b>Data Type</b> | UINT |
| <b>Attribute</b> | 0x02       | <b>Access</b>    | Get  |

Returns the Device Type code.

### 11.1.3 ProductCode

|           |             |           |           |
|-----------|-------------|-----------|-----------|
| Name:     | ProductCode |           |           |
| Class     | 0x01        | Default   | See below |
| Instance  | 0x01        | Data Type | UINT      |
| Attribute | 0x03        | Access    | Get       |

Identifies the current drive configuration, and is used to link a node to the installed EDS files. ProductCode is calculated as shown below.

**Table 11.2 Generic ProductCode**

| b15 | b14 | b13 | b12        | b11 | b10                         | b9 | b8 | b7 | b6                                    | b5 | b4 | b3 | b2 | b1 | b0 |
|-----|-----|-----|------------|-----|-----------------------------|----|----|----|---------------------------------------|----|----|----|----|----|----|
| 0   |     |     | Drive Type |     | Variant<br>Pr <b>11.028</b> |    |    |    | Drive Mode<br>(Pr <b>11.084</b> ) - 1 |    |    | 0  |    |    |    |

Drive Type returns the code for the product (i.e. the drive). This is 2 for Unidrive M600 to M810, and 3 for Unidrive M100 to 400.

Pr **11.028** returns the drive derivative number.

Pr **11.084** returns the drive operating mode, e.g. Open-loop = 1, RFC-A = 2, RFC-S = 3, Regen = 4, etc.

In advanced mode, ProductCode is calculated as shown below.

**Table 11.3 Advanced ProductCode**

| b15     | b14 | b13 | b12   | b11 | b10 | b9 | b8               | b7 | b6 | b5     | b4 | b3 | b2     | b1 | b0 |
|---------|-----|-----|---|-----|-----|----|------------------|----|----|--------|----|----|--------|----|----|
| Product |     |     | $((\text{Pr } 11.029/100) * 3) + \text{Local Slot}$ |     |     |    | Pr <b>11.084</b> |    |    | Slot X |    |    | Slot Y |    |    |

Pr **11.029** returns the major software revision number.

Local Slot indicates the slot in which the SI-DeviceNet is installed: 0 = slot 1, 1 = slot 2, 2 = slot 3.

Pr **11.084** returns the drive operating mode, e.g. open loop, closed loop, servo, etc.

Slot X indicates the family of installed in the lowest numbered slot, excluding the slot where this SI-DeviceNet is installed. Slot X = Pr **MM.001**/100.

Slot Y indicates the family of installed in the highest numbered slot, excluding the slot where this SI-DeviceNet is installed. Slot Y = Pr **MM.001**/100.

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary / Terms        |
| Index                   |

### 11.1.4 Revision

|                  |          |                  |                |
|------------------|----------|------------------|----------------|
| <b>Name:</b>     | Revision |                  |                |
| <b>Class</b>     | 0x01     | <b>Default</b>   | N/A            |
| <b>Instance</b>  | 0x01     | <b>Data Type</b> | ARRAY of USINT |
| <b>Attribute</b> | 0x04     | <b>Access</b>    | Get            |

Identifies the revision of the drive. Revision is calculated as shown below.

|                                      |            |            |            |            |            |           |           |           |           |           |           |           |           |           |           |
|--------------------------------------|------------|------------|------------|------------|------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| <b>b15</b>                           | <b>b14</b> | <b>b13</b> | <b>b12</b> | <b>b11</b> | <b>b10</b> | <b>b9</b> | <b>b8</b> | <b>b7</b> | <b>b6</b> | <b>b5</b> | <b>b4</b> | <b>b3</b> | <b>b2</b> | <b>b1</b> | <b>b0</b> |
| ((Pr 11.029 mod 1000000) / 10000 +1) |            |            |            |            |            |           |           | 0         | 127       |           |           |           |           |           |           |

### 11.1.5 SerialNumber

|                  |              |                  |       |
|------------------|--------------|------------------|-------|
| <b>Name:</b>     | SerialNumber |                  |       |
| <b>Class</b>     | 0x01         | <b>Default</b>   | N/A   |
| <b>Instance</b>  | 0x01         | <b>Data Type</b> | UDINT |
| <b>Attribute</b> | 0x06         | <b>Access</b>    | Get   |

Returns a serial number of the SI-DeviceNet. This value is entered during production, and cannot be edited. The serial number of the SI-DeviceNet can also be read from Pr **MM.004** and Pr **MM.005**.

### 11.1.6 ProductName

|                  |             |                  |              |
|------------------|-------------|------------------|--------------|
| <b>Name:</b>     | ProductName |                  |              |
| <b>Class</b>     | 0x01        | <b>Default</b>   | SM DeviceNet |
| <b>Instance</b>  | 0x01        | <b>Data Type</b> | SHORT_STRING |
| <b>Attribute</b> | 0x07        | <b>Access</b>    | Get          |

Returns a short string to indicate the Product Name. The SI-DeviceNet returns the string "SI DeviceNet".



## 11.2 SI-DeviceNet Object

Class: 0x03 (3)

The DeviceNet Object provides the configuration and status of the SI-DeviceNet port.

### 11.2.1 MAC-ID

|                  |        |                  |         |
|------------------|--------|------------------|---------|
| <b>Name:</b>     | MAC-ID |                  |         |
| <b>Class</b>     | 0x03   | <b>Default</b>   | 63      |
| <b>Instance</b>  | 0x01   | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x01   | <b>Access</b>    | Get/Set |

The MAC-ID is read from Pr **S.01.004** at power up and reset. When this attribute is written to, the SI-DeviceNet will update the MAC-ID in Pr **S.01.004** and reset, causing the new value to take effect immediately.

### 11.2.2 DataRate

|                  |          |                  |         |
|------------------|----------|------------------|---------|
| <b>Name:</b>     | DataRate |                  |         |
| <b>Class</b>     | 0x03     | <b>Default</b>   | 0       |
| <b>Instance</b>  | 0x01     | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x02     | <b>Access</b>    | Get/Set |

The Data Rate is read from Pr **S.01.007** at power up and reset. When this attribute is written to, the SI-DeviceNet will update the Data Rate in Pr **S.01.007**. The new value is not stored automatically, and the SI-DeviceNet is not reset.

Table 11.4 shows the attribute values for each data rate.

**Table 11.4 DeviceNet data rate**

| Setting | bits/sec |
|---------|----------|
| 0       | 125K     |
| 1       | 250K     |
| 2       | 500K     |

### 11.2.3 AllocationByte

|                  |                |                  |       |
|------------------|----------------|------------------|-------|
| <b>Name:</b>     | AllocationByte |                  |       |
| <b>Class</b>     | 0x03           | <b>Default</b>   | 0     |
| <b>Instance</b>  | 0x01           | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x05           | <b>Access</b>    | Get   |

Returns 2 bytes of information. The low byte contains the Allocation Byte, with each bit assigned as shown in the table below.

The high byte indicates the MAC-ID of the master device which allocated the Master/Slave pre-defined connection set. A value of 255 means the pre-defined Master/Slave connection set has not yet been allocated.

**Table 11.5 Allocation byte**

| <b>Bit</b> | <b>Action</b>                   |
|------------|---------------------------------|
| 0          | Explicit Message                |
| 1          | Polled                          |
| 2          | Strobed (Not supported)         |
| 3          | Reserved                        |
| 4          | Change of State (Not supported) |
| 5          | Cyclic (Not supported)          |
| 6          | Acknowledge Suppression         |
| 7          | Reserved                        |

## 11.3 Motor Data Object

Class: 0x28 (40)

### 11.3.1 MotorType

|                  |            |                  |         |
|------------------|------------|------------------|---------|
| <b>Name:</b>     | MotorType1 |                  |         |
| <b>Class</b>     | 0x28       | <b>Default</b>   | 7       |
| <b>Instance</b>  | 0x01       | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x03       | <b>Access</b>    | Get/Set |
| <b>Name:</b>     | MotorType2 |                  |         |
| <b>Class</b>     | 0x28       | <b>Default</b>   | 7       |
| <b>Instance</b>  | 0x02       | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x03       | <b>Access</b>    | Get/Set |

There are 2 instances of the Motor Data object. Instance 1 will represent the Menu 5 motor information (Motor Map 1) and instance 2 will represent the menu 21 motor map (Motor Map 2). The instance being used by the other dependant DeviceNet objects will be determined by Pr **21.015**. Pr **21.015** is polled in the background task, so the user should be aware that during motor map changeover, the rpm speed reference might not be accurate.

MotorType1 is linked directly to Pr **S.01.040**, and MotorType2 is linked directly to Pr **S.01.041**.

**Table 11.6 Supported motor types**

| Pr <b>S.01.040</b> ,<br>Pr <b>S.01.041</b> | Motor Type                              |
|--|---|
| 2  | Field Controlled DC Motor               |
| 6  | Wound Rotor Induction motor             |
| 7  | Squirrel Cage Induction Motor (default) |
| 9  | Sinusoidal PM BL motor                  |
| 10   | Trapezoidal PM BL motor                 |

### 11.3.2 RatedCurrent

|                  |               |                  |                  |
|------------------|---------------|------------------|------------------|
| <b>Name:</b>     | RatedCurrent1 |                  |                  |
| <b>Class</b>     | 0x28          | <b>Default</b>   | Pr <b>05.007</b> |
| <b>Instance</b>  | 0x01          | <b>Data Type</b> | USINT            |
| <b>Attribute</b> | 0x06          | <b>Access</b>    | Get/Set          |
| <b>Name:</b>     | RatedCurrent2 |                  |                  |
| <b>Class</b>     | 0x28          | <b>Default</b>   | Pr <b>21.007</b> |
| <b>Instance</b>  | 0x02          | <b>Data Type</b> | USINT            |
| <b>Attribute</b> | 0x06          | <b>Access</b>    | Get/Set          |

Specifies the rated current of the motor in Amps. Instance 1 is mapped to Pr **05.007** in the drive, while instance 2 is mapped to Pr **21.007**.

Set Pr **05.007** = RatedCurrent1 \* 10

Get RatedCurrent1 = Pr **05.007** / 10

Set Pr **21.007** = RatedCurrent2 \* 10

Get RatedCurrent2 = Pr **21.007** / 10

### 11.3.3 RatedVoltage

|           |               |           |                  |
|-----------|---------------|-----------|------------------|
| Name:     | RatedVoltage1 |           |                  |
| Class     | 0x28          | Default   | Pr <b>05.009</b> |
| Instance  | 0x01          | Data Type | USINT            |
| Attribute | 0x07          | Access    | Get/Set          |

|           |               |           |                  |
|-----------|---------------|-----------|------------------|
| Name:     | RatedVoltage2 |           |                  |
| Class     | 0x28          | Default   | Pr <b>21.009</b> |
| Instance  | 0x02          | Data Type | USINT            |
| Attribute | 0x07          | Access    | Get/Set          |

Specifies the rated motor voltage in Volts. Instance 1 is mapped directly to Pr **05.009** in the **drive**, and instance 2 is mapped directly to Pr **21.009**.

### 11.3.4 RatedFreq

|           |            |           |         |
|-----------|------------|-----------|---------|
| Name:     | RatedFreq1 |           |         |
| Class     | 0x28       | Default   |         |
| Instance  | 0x01       | Data Type | USINT   |
| Attribute | 0x09       | Access    | Get/Set |

|           |            |           |         |
|-----------|------------|-----------|---------|
| Name:     | RatedFreq2 |           |         |
| Class     | 0x28       | Default   |         |
| Instance  | 0x02       | Data Type | USINT   |
| Attribute | 0x09       | Access    | Get/Set |

Specifies the rated motor frequency in Hertz. Instance 1 is linked to Pr **05.006** in the Unidrive M and instance 2 is linked to Pr **21.006**.

Set Pr **05.006** = RatedFreq1 \* 10

Get RatedFreq1 = Pr **05.006** / 10

Set Pr **21.006** = RatedFreq2 \* 10

Get RatedFreq2 = Pr **21.006** / 10

### 11.3.5 BaseSpeed

|           |            |           |                  |
|-----------|------------|-----------|------------------|
| Name:     | BaseSpeed1 |           |                  |
| Class     | 0x28       | Default   | Pr <b>05.008</b> |
| Instance  | 0x01       | Data Type | USINT            |
| Attribute | 0x0F       | Access    | Get/Set          |

|           |            |           |                  |
|-----------|------------|-----------|------------------|
| Name:     | BaseSpeed2 |           |                  |
| Class     | 0x28       | Default   | Pr <b>21.008</b> |
| Instance  | 0x02       | Data Type | USINT            |
| Attribute | 0x0F       | Access    | Get/Set          |

Specifies the base speed of the motor in rpm. Instance 1 is mapped directly to Pr **05.008** in the **drive**, and instance 2 is mapped directly to Pr **21.008**.

### 11.3.6 Motor2Select

|                  |              |                  |         |
|------------------|--------------|------------------|---------|
| <b>Name:</b>     | Motor2Select |                  |         |
| <b>Class</b>     | 0x28         | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01         | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x64         | <b>Access</b>    | Get/Set |

Selects between Motor Map 1 and Motor Map 2 in the drive.

Set Pr **11.045**

Get Pr **21.015**

|                          |
|--------------------------|
| Safety Information       |
| Introduction             |
| Mechanical Installation  |
| Electrical Installation  |
| Getting started          |
| Parameters               |
| Non cyclic data          |
| Control / status word    |
| EDS Files                |
| Advanced Features        |
| <b>DeviceNet Objects</b> |
| Diagnostics              |
| Glossary/Of Terms        |
| Index                    |

## 11.4 Control Supervisor

Class: 0x29 (41)

### 11.4.1 RunFwd

|                  |        |                  |         |
|------------------|--------|------------------|---------|
| <b>Name:</b>     | RunFwd |                  |         |
| <b>Class</b>     | 0x29   | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01   | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x03   | <b>Access</b>    | Get/Set |

Set to 1 to run the drive in the forward direction.

Get/Set Pr **06.042** bit 1

### 11.4.2 RunRev

|                  |        |                  |         |
|------------------|--------|------------------|---------|
| <b>Name:</b>     | RunRev |                  |         |
| <b>Class</b>     | 0x29   | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01   | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x04   | <b>Access</b>    | Get/Set |

Set to 1 to run the drive in the reverse direction.

Get/Set Pr **06.042** bit 3

### 11.4.3 NetCtrl

|                  |         |                  |         |
|------------------|---------|------------------|---------|
| <b>Name:</b>     | NetCtrl |                  |         |
| <b>Class</b>     | 0x29    | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01    | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x05    | <b>Access</b>    | Get/Set |

Switches the drive between terminal and fieldbus control.

Get/Set Pr **06.042** bit 7

Set False terminal control

Set True fieldbus control

### 11.4.4 State

|                  |       |                  |       |
|------------------|-------|------------------|-------|
| <b>Name:</b>     | State |                  |       |
| <b>Class</b>     | 0x29  | <b>Default</b>   | N/A   |
| <b>Instance</b>  | 0x01  | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x05  | <b>Access</b>    | Get   |

This returns a code to indicate the current operating state of the drive.

**Table 11.7 Device state**

| State | DeviceNet state | Drive state  |
|-------|-----------------|--|
| 1     | Startup         | This state is skipped on   |
| 2     | Not_Ready       | Inhibit  |
| 3     | Ready           | Ready  |
| 4     | Enabled         | Run or Stop (stop is only enabled by default in Servo mode)      |
| 5     | Stopping        | Deceleration or Injection  |
| 6     | Fault_Stop      | AC_UU (this will only occur if Mains Loss is enabled)            |
| 7     | Faulted         | Tripped  |
| 0     | Vendor Specific | All other drive states, e.g. Scan, Orienting, Regen Active, etc. |

### 11.4.5 RunningFwd

|                  |            |                  |       |
|------------------|------------|------------------|-------|
| <b>Name:</b>     | RunningFwd |                  |       |
| <b>Class</b>     | 0x29       | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01       | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x07       | <b>Access</b>    | Get   |

Indicates that the drive is running in the forward direction.

Get True (Pr **10.040** & 0x2002) == 0x0002

Get False (Pr **10.040** & 0x2002) != 0x0002

### 11.4.6 RunningRev

|                  |            |                  |       |
|------------------|------------|------------------|-------|
| <b>Name:</b>     | RunningRev |                  |       |
| <b>Class</b>     | 0x29       | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01       | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x08       | <b>Access</b>    | Get   |

Indicates that the drive is running in the reverse direction.

Get True (Pr **10.040** & 0x2002) == 0x2002

Get False (Pr **10.040** & 0x2002) != 0x2002

### 11.4.7 Faulted

|                  |         |                  |       |
|------------------|---------|------------------|-------|
| <b>Name:</b>     | Faulted |                  |       |
| <b>Class</b>     | 0x29    | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01    | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x0A    | <b>Access</b>    | Get   |

Indicates that the drive is tripped, i.e. not OK

Get Pr **10.001**

### 11.4.8 FaultRst

|                  |          |                  |       |
|------------------|----------|------------------|-------|
| <b>Name:</b>     | FaultRst |                  |       |
| <b>Class</b>     | 0x29     | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01     | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x0C     | <b>Access</b>    | Set   |

Resets the drive from a tripped condition.

Set True Pr **10.038** = 100

Set False No action

### 11.4.9 FaultCode

|                  |          |                  |       |
|------------------|----------|------------------|-------|
| <b>Name:</b>     | FaultRst |                  |       |
| <b>Class</b>     | 0x29     | <b>Default</b>   | N/A   |
| <b>Instance</b>  | 0x01     | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x0D     | <b>Access</b>    | Set   |

If the drive is tripped, the fault code is obtained from parameter Pr **10.020** in the drive. If the fault code in Pr **10.020** is one of the following, the table gives the appropriate ODVA code, otherwise the error code will be returned as 0x1000 + Pr **10.020**.

#### Fault codes

| Drive fault code | ODVA fault code |
|------------------|-----------------|
| 2                | 0x3210          |
| 3                | 0x2300          |
| 4                | 0x7112          |
| 6                | 0x9000          |
| 20               | 0x2310          |
| 21               | 0x4300          |
| 26               | 0x5112          |
| 32               | 0x3130          |

### 11.4.10 CtrlFromNet

|                  |             |                  |       |
|------------------|-------------|------------------|-------|
| <b>Name:</b>     | CtrlFromNet |                  |       |
| <b>Class</b>     | 0x29        | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01        | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x0F        | <b>Access</b>    | Get   |

Indicates that the drive is operating under fieldbus control.

Get Pr **06.042** bit 7 & Pr **06.043**



### 11.4.11 DriveEnable

|                  |             |                  |         |
|------------------|-------------|------------------|---------|
| <b>Name:</b>     | DriveEnable |                  |         |
| <b>Class</b>     | 0x29        | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01        | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x0F        | <b>Access</b>    | Get/Set |

Enables the drive. This puts the Drive into the “Ready” state, allowing the RunFwd and RunRev attributes to control the drive. RunFwd and RunRev will have no effect if DriveEnable is not set to 1.

Get/Set Pr **06.042** bit 0

**NOTE** The external hardware enable signal must also be present before the drive will go to the Ready state.

## 11.5 AC/DC Drive Object

**Class:** 0x2A (42)

### 11.5.1 AtReference

|                  |             |                  |       |
|------------------|-------------|------------------|-------|
| <b>Name:</b>     | AtReference |                  |       |
| <b>Class</b>     | 0x2A        | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01        | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x03        | <b>Access</b>    | Get   |

Indicates that the drive is running at the requested speed.

Get Pr **10.006**

### 11.5.2 NetRef

|                  |        |                  |         |
|------------------|--------|------------------|---------|
| <b>Name:</b>     | NetRef |                  |         |
| <b>Class</b>     | 0x2A   | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01   | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x04   | <b>Access</b>    | Get/Set |

Selects the source of the speed reference. Analog input 1 is used as the speed reference when running under local control, with Digital Speed Reference 1 being used as the speed reference for network control.

Get/Set Pr **06.042** bit 8

Set False analog speed reference

Set True digital speed reference

The reference can only be changed between local and remote when the drive is configured in speed control mode. If a change is requested when in torque mode then a ‘Device state conflict’ error code 10h will be returned.

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| Devicenet Objects       |
| Diagnostics             |
| Glossary/Of Terms       |
| Index                   |

### 11.5.3 DriveMode

|                  |           |                  |         |
|------------------|-----------|------------------|---------|
| <b>Name:</b>     | DriveMode |                  |         |
| <b>Class</b>     | 0x2A      | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01      | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x06      | <b>Access</b>    | Get/Set |

DriveMode does not allow the operating mode of the drive to be changed. Pr **04.011** will be written to as shown in Table 11.9, provided that the drive is already in the correct operating mode.

**Table 11.8 Get DriveMode**

| DriveMode | Drive Mode        | Pr 11.031 | Pr 04.011 |
|-----------|-------------------|-----------|-----------|
| 1         | Open Loop Speed   | 0, 1      | 0         |
| 2         | Closed Loop Speed | 2, 3      | 0         |
| 3         | Torque Control    | N/A       | 1         |
| 0         | User Defined      | 4         | 0         |

**Table 11.9 Set DriveMode**

| DriveMode | Drive Mode        | Pr 11.031  | Pr 04.011 | Comment  |
|-----------|-------------------|------------|-----------|--|
| 0         | Vendor Specific   | 4          | N/A       | Pr <b>11.031</b> will never be changed by setting the DriveMode attribute. An error (0x10) will be generated if the requested DriveMode value corresponds to the current drive operating mode. |
| 1         | Open Loop Speed   | 0, 1       | 0         |  |
| 2         | Closed Loop Speed | 2, 3       | 0         |  |
| 3         | Torque Control    | 0, 1, 2, 3 | 1         |  |
| 4         | Process Control   | N/A        |           |  |
| 5         | Position Control  | N/A        |           |  |

### 11.5.4 SpeedActual

|                  |             |                  |       |
|------------------|-------------|------------------|-------|
| <b>Name:</b>     | SpeedActual |                  |       |
| <b>Class</b>     | 0x2A        | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01        | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x07        | <b>Access</b>    | Get   |

Returns the actual speed of the motor in RPM. The source of the motor speed depends on the operating mode of the drive.

Get Pr **05.004** (Open Loop)

Get Pr **03.002** (Closed Loop, Servo)

### 11.5.5 SpeedRef

|                  |          |                  |         |
|------------------|----------|------------------|---------|
| <b>Name:</b>     | SpeedRef |                  |         |
| <b>Class</b>     | 0x2A     | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01     | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x08     | <b>Access</b>    | Get/Set |

Sets the speed reference in RPM. As the drive uses units of Hz for speed, these values are converted when reading from or writing to this attribute.

Set Pr **01.021** = (RPM \* Pole Pairs) / 6 (Open Loop)

Get RPM = (Pr **02.001** \* 6) / Pole Pairs (Open Loop)

Get/Set Pr **01.021** \* 10 (Closed Loop, Servo)

### 11.5.6 TorqueActual

|                  |              |                  |       |
|------------------|--------------|------------------|-------|
| <b>Name:</b>     | TorqueActual |                  |       |
| <b>Class</b>     | 0x2A         | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01         | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x0B         | <b>Access</b>    | Get   |

Returns the actual load on the motor as a percentage of the rated motor load. This attribute has 1 decimal place fixed precision, so a value of 1000 represents 100.0 % load.

Get Pr **04.020**

### 11.5.7 TorqueRef

|                  |           |                  |         |
|------------------|-----------|------------------|---------|
| <b>Name:</b>     | TorqueRef |                  |         |
| <b>Class</b>     | 0x2A      | <b>Default</b>   |         |
| <b>Instance</b>  | 0x01      | <b>Data Type</b> | USINT   |
| <b>Attribute</b> | 0x0C      | <b>Access</b>    | Get/Set |

Sets the load (torque) reference as % of rated motor load (torque). This attribute has 1 decimal place fixed precision, so a value of 1000 represents 100.0 % load.

Set Pr **04.008** = TorqueRef / 10

Get Torque Ref = Pr **04.008** \* 10

### 11.5.8 RefFromNet

|                  |            |                  |       |
|------------------|------------|------------------|-------|
| <b>Name:</b>     | RefFromNet |                  |       |
| <b>Class</b>     | 0x2A       | <b>Default</b>   |       |
| <b>Instance</b>  | 0x01       | <b>Data Type</b> | USINT |
| <b>Attribute</b> | 0x0C       | <b>Access</b>    | Get   |

Indicates the source of the speed reference.

TRUE if Pr **01.049** = 3 and Pr **01.050** = 1

FALSE otherwise.

## 11.6 Control Techniques Object

Class code: 0x64 (100)

The Control Techniques object provides access to all drive parameters. For example, parameter Pr **04.020** would be accessed as Class 100, Instance 4, Attribute 20.

**Table 11.10 Supported objects**

| Instance  | Menu | Name  |
|-----------|------|---|
| 1 (0x01)  | 1    | Speed reference.                            |
| 2 (0x02)  | 2    | Ramp control.                               |
| 3 (0x03)  | 3    | Speed control.                              |
| 4 (0x04)  | 4    | Current control.                            |
| 5 (0x05)  | 5    | Motor control.                              |
| 6 (0x06)  | 6    | Sequencing.                                 |
| 7 (0x07)  | 7    | Analog I/O.                                 |
| 8 (0x08)  | 8    | Digital I/O.                                |
| 9 (0x09)  | 9    | Logic.                                      |
| 10 (0x0A) | 10   | Drive status.                               |
| 11 (0x0B) | 11   | Drive set-up.                               |
| 12 (0x0C) | 12   | Programmable thresholds.                    |
| 13 (0x0D) | 13   | Position control.                           |
| 14 (0x0E) | 14   | Process PID loop.                           |
| 15 (0x0F) | 15   | Slot 1 configuration.                       |
| 16 (0x10) | 16   | Slot 2 configuration.                       |
| 17 (0x11) | 17   | Slot 3 configuration.                       |
| 18 (0x12) | 18   | User application menu 1.                    |
| 19 (0x13) | 19   | User application menu 2 (not on M100-M400). |
| 20 (0x14) | 20   | User application menu 3 (not on M100-M400). |
| 21 (0x15) | 21   | Second motor map.                           |
| 200       | 0    | Menu 0.                                     |

# 12 Diagnostics

## 12.1 Overview

This section provides basic diagnostic information intended to resolve the most common problems encountered when setting up an SI-DeviceNet module on a DeviceNet network.

A high percentage of problems reported are basic set-up problems which can usually be solved by reading the information in this chapter. If after reading this chapter you are still experiencing problems, please contact your supplier for support.

### 12.1.1 Drive trip display codes

If the option module detects an error during operation, it will force a trip on the drive. However, the trip string displayed on the drive will only indicate which slot initiated the trip. The exact reason for the trip will be indicated in the drive trip code parameters (Pr **10.020** and Pr **10.070**).

Table 12.1 shows the possible trips that will be displayed on the drive when a problem is detected with the option module or when the option module initiates a trip.

**Table 12.1 Drive trip display codes**

| Trip             | Description   |
|------------------|---|
| SlotX HF         | The drive has detected that an option module is present but is unable to communicate with it due to a hardware fault.   |
| SlotX Error      | User trip generated by the option module  |
| SlotX Not Fitted | This trip will occur if a drive slot was previously configured with an option module but on power up, no option module was detected.  |
| SlotX Different  | This trip will occur if a drive slot was previously configured with an option module but on power up, a different option module was detected. Replacing the option module with another one of the same ID number will not initiate this trip.<br>The trip will also occur if an option module is installed to a previously unused slot. |

### 12.1.2 Module error codes

If the option module detects an internal error during operation, it will force a trip on the drive and provide a sub-trip string for a clearer definition of the trip. The table below shows the possible module error codes.

**Table 12.2 Module error codes**

| Value | Text             | Description   |
|-------|------------------|---|
| 200   | SW fault         | Software fault  |
| 201   | BG Orun          | Background task overrun                                   |
| 202   | FW invalid       | Invalid firmware for hardware version                     |
| 203   | Drv unknown      | Unknown drive type  |
| 204   | Drv unsupported  | Unsupported drive type                                    |
| 205   | Mode unknown     | Unknown mode  |
| 206   | Mode unsupported | Unsupported mode  |
| 207   | FLASH corrupt    | Corrupted Non-volatile Flash                              |
| 208   | Dbase init       | Database initialization error                             |
| 209   | FS init          | File system initialization error                          |
| 210   | Memory alloc     | Memory allocation error                                   |
| 211   | Filesystem       | File system error   |
| 212   | Configuration    | Configuration file error                                  |
| 213   | OHT              | Overheated  |
| 214   | TO drv           | The drive has not responded with the watchdog period      |
| 215   | eCMP             | eCMP comms failure  |
| 216   | TO eCMP slot 1   | Slot 1 eCMP timeout                                       |
| 217   | TO eCMP slot 2   | Slot 2 eCMP timeout                                       |
| 218   | TO eCMP slot 3   | Slot 3 eCMP timeout                                       |
| 219   | TO eCMP slot 4   | Slot 4 eCMP timeout                                       |
| 220   | Fact Setting     | Missing factory setting                                   |
| 221   | Config Load      | Error loading saved configuration file                    |
| 222   | RT Config        | Failed to update parameter after drive mode being changed |
| 223   | Read Par         | Failed to read parameter during cyclic communication      |
| 224   | Write Par        | Failed to write parameter during cyclic communication     |

### 12.1.3 DeviceNet error codes

If the SI-DeviceNet module detects a DeviceNet error during operation, it will force a trip on the drive and provide a sub-trip string for a clearer definition of the trip. The table below shows all possible SI-DeviceNet error codes.

**Table 12.3 DeviceNet network error codes**

| Value | Text      | Description   |
|-------|-----------|---|
| 0     | No trip   | No trip   |
| 100   | Link Loss | The link to the network has been lost                     |
| 101   | Bus Off   | The CAN layer of the module has entered the Bus Off state |

### 12.1.4 SI-DeviceNet network diagnostic

The operating status of the SI-DeviceNet module can be viewed in the network diagnostic parameter (Pr **S.01.006**). All possible values of this parameter are described in Table 12.4.

**Table 12.4 SI-DeviceNet network operating status**

| Value | Text           | Description  |
|-------|----------------|--|
| 0     | Network OK     | Network ok/healthy   |
| 1     | Init OK        | The SI-DeviceNet has initialized correctly and is waiting for the DeviceNet master to initialize communications.                             |
| 2     | No Cyclic      | No cyclic data has been recognized. This could be due to the length of the mapping data is not equal to the master setup.                    |
| 3     | Init Failed    | A part of the SI-DeviceNet initialization sequence was not successful. If this fault persists after a power-cycle, replace the SI-DeviceNet. |
| 4     | Comm Fault     | Fault found in the communications of the module. This could be due to different devices being configured to use different baud rates.        |
| 5     | No 24 V        | No 24 V external PSU has been detected.  |
| 6     | Baud detecting | Automatic baud rate detection is in progress.  |
| 7     | Initializing   | The module is currently initializing.  |

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| <b>Diagnostics</b>      |
| Glossary/Of Terms       |
| Index                   |

### 12.1.5 Mapping Status

If the DeviceNet Network Diagnostic parameter (Pr **S.01.006**) indicates "Init Failed", a mapping configuration error has been could have been detected. The reason for the error is indicated by the SI-DeviceNet input mapping status parameter (Pr **S.01.022**) and the SI-DeviceNet output mapping status parameter (Pr **S.01.023**).

When a mapping error has been corrected, reset the SI-DeviceNet module by setting Pr**S.01.002** or MM.007 to On (1).

The mapping error codes are described in Table 12.5.

**Table 12.5 Mapping error codes**

| Value | Text             | Description   |
|-------|------------------|---|
| 0     | No error         | No error has been detected during mapping initialisation  |
| 1     | Par impossible   | The parameter may not exist or may not be readable  |
| 2     | Hole in mapping  | Cyclic data mapping parameters are not contiguous   |
| 3     | Dup mapping      | Two or more cyclic data mapping configuration parameters have been configured with the same destination parameter reference |
| 4     | Length exceed    | The length of the mapped parameters exceeds the length of the selected assembly object                                      |
| 5     | Obj not support  | The selected assembly object is not supported   |
| 6     | Pre & uncompress | If the predefined object is selected, the data alignment must be set to 16 bits   |
| 7     | Type unmatched   | The IN and OUT objects both must be predefined objects, or neither  |
| 8     | Memory fault     | Failed to allocate memory for mapping   |
| 9     | No mapping       | No parameter is assigned to the mapping   |
| 10    | Reserved         | Reserved  |

### 12.1.6 Alarms

If the SI-DeviceNet detects an alarm during operation, it will cause the drive to display the appropriate alarm on the drive keypad. If more than one alarm is present, it will be shown as "first-in-first-out" (FIFO) order.

| Value | Text        | Description  |
|-------|-------------|--|
| 0     | No alarm    | No alarm.  |
| 1     | User Prog   | A user program alarm has been generated.   |
| 2     | eCMP        | An eCMP alarm has been generated.  |
| 3     | FS Usage    | A file system alarm has been generated.  |
| 4     | Too Hot     | Module temperature is too high.  |
| 5     | In Mapping  | Error with Input mapping setup.  |
| 6     | Out Mapping | Error with Output mapping setup.   |
| 7     | Fbus Init   | Fieldbus Initialization failed, possibly due to external 24 V missing or baud rate detection failed. |
| 8     | Read Err    | Error during reading from a mapped parameter.  |
| 9     | Write Err   | Error during writing to a mapped parameter.  |



# 13 Glossary Of Terms

**Address:** This is the unique network identification given to a networked device to allow communication on a network. When a device sends or receives data the address is used to determine the source and the destination of the message.

**Alignment:** By default SI-DeviceNet transmits values as 32 bits on the network. It is possible by using alignment to reduce the number of bits transmitted when sending 16-bit (or smaller) values on the network to 16-bit (32-bit values will still be transmitted as 32-bit values). This has the advantage of reducing the volume of traffic on the network and allowing more parameters to be mapped within SI-DeviceNet.

**Bit:** A binary digit, this may have the value of 1 or 0.

**Byte:** A collection of 8 binary digits that collectively store a value. This may be signed or unsigned.

**CAN:** The base network used for DeviceNet. The DeviceNet module does not support CAN commands.

**DeviceNet:** Builds on the basic CAN protocol by offering higher level functionality.

**Casting:** The process of changing between data sizes without changing the value represented, e.g. changing from 16-bit to 32-bit.

**Consistency:** Describes how data is transmitted between nodes on the network. If data is consistent it is transmitted from node to node as a single entity. Thus preventing data corruption where multiple bytes are transmitted or received individually.

**Control word:** A collection of binary digits that are used to control the drive. Features typically include directional controls, run controls and other similar functions.

**Cyclic data:** This consists of values that are sent at regular or cyclic intervals across the network. A typical use of cyclic data would be the transmission of a speed reference or a control word.

**Data format:** Determines the quantity and function of the data sent and received across the network.

**Data rate:** Determines the communication speed of the network, the higher the value the more data can be sent across the network in the same time period.

**Device:** A piece of equipment connected to a network, this may be any type of equipment including repeaters, hubs, masters or slaves.

**Double word:** A 32-bit word, this may be signed or unsigned.

**Earthing/Grounding:** Describes the electrical safety or shielding connections for the module.

|                          |
|--------------------------|
| Safety Information       |
| Introduction             |
| Mechanical Installation  |
| Electrical Installation  |
| Getting started          |
| Parameters               |
| Non cyclic data          |
| Control / status word    |
| EDS Files                |
| Advanced Features        |
| DeviceNet Objects        |
| Diagnostics              |
| <b>Glossary Of Terms</b> |
| Index                    |

**Event task:** A special way to use a message or change of state to trigger a software routine.

**IN data:** Data that is returned from a slave device to the DeviceNet master.

**Long word:** A 32-bit data word that may be signed or unsigned.

**Mapping:** The process of linking DeviceNet values to parameters within the drive.

**Master:** The controlling device on the network, generally this will include programming features.

**Network Loss Trip:** A method to determine when a node has lost contact with the master.

**Node:** A device on the network. This may be either a device such as a drive or part of the network such as a repeater.

**Non-Cyclic Data:** Data that is requested or sent by the master as required. This is not sent on a regular basis and generally allows access to any parameter. This is useful for occasional changes or configuration purposes.

**Object Dictionary:** A collection of the objects that are supported by the product.

**Poll rate:** The rate at which cyclic data is sent and received on the network.

**Response ID:** The response code of the message received when using PPO4 word non-cyclic communication.

**Scan rate:** See Poll rate in this section.

**Shielding:** A connection to provide additional immunity to noise used on a network cable.

**Segment:** An electrically separate part of the network. Each segment requires correct termination to ensure reliable operation. Due to electrical limitations the maximum number of devices on a segment is limited to 32.

**Slave:** A device on the DeviceNet network such as a drive or sensor. A slave device will only respond to messages from a master.

**Status word:** A value that denotes the status of the drive. Each bit within the word will have a specific meaning.

**Task ID:** The code used to describe the purpose of a message using PPO 4 word non-cyclic communication.

**Termination:** This is used at both ends of a network segment to prevent reflections and reduce noise.

**Watchdog:** A method used to determine if a communication system is ok/healthy. A typical watchdog scheme uses a handshaking system to check both the master and slave are participating in communications.

**Word:** A collection of 16 binary digits.

|                          |
|--------------------------|
| Safety Information       |
| Introduction             |
| Mechanical Installation  |
| Electrical Installation  |
| Getting started          |
| Parameters               |
| Non cyclic data          |
| Control / status word    |
| EDS Files                |
| Advanced Features        |
| DeviceNet Objects        |
| Diagnostics              |
| <b>Glossary Of Terms</b> |
| Index                    |

---

# Index

---

|  |    |
|--|----|
| <b>A</b>                                 |    |
| Above set speed .....                    | 48 |
| At speed .....                           | 47 |
| <b>B</b>                                 |    |
| Back-up power supply .....               | 9  |
| Below set speed .....                    | 47 |
| <b>C</b>                                 |    |
| Cable .....                              | 13 |
| Cautions .....                           | 5  |
| Compliance with regulations .....        | 6  |
| Conformance certificate .....            | 10 |
| Control and status words .....           | 45 |
| Control Techniques Object .....          | 68 |
| Control word .....                       | 45 |
| Control word bit functions .....         | 46 |
| Current limit .....                      | 48 |
| Cyclic data .....                        | 44 |
| <b>D</b>                                 |    |
| Date code .....                          | 10 |
| DeviceNet cable .....                    | 13 |
| DeviceNet ground point .....             | 15 |
| DeviceNet network termination .....      | 14 |
| Drive active .....                       | 47 |
| Dynamic brake active .....               | 48 |
| <b>E</b>                                 |    |
| Electrical installation .....            | 12 |
| Electrical safety .....                  | 5  |
| Environmental limits .....               | 6  |
| Explicit parameter access .....          | 44 |
| External power supply .....              | 13 |
| External supply .....                    | 12 |
| <b>G</b>                                 |    |
| General installation .....               | 11 |
| General specification .....              | 9  |
| Generic EDS files .....                  | 49 |
| Getting started .....                    | 16 |
| Glossary of terms .....                  | 73 |
| <b>H</b>                                 |    |
| Hardware enable .....                    | 45 |
| <b>M</b>                                 |    |
| Maximum network length .....             | 15 |
| Minimum node to node cable length .....  | 15 |
| Module menu 0 - Module Information ..... | 25 |
| Module menu 1 - DeviceNet Setup .....    | 28 |

|   |    |
|---|----|
| Module menu 2 .....                         | 40 |
| Module menu 3 .....                         | 41 |
| Module menu 4 .....                         | 42 |
| <b>O</b>                                    |    |
| Option Module identification .....          | 10 |
| <b>P</b>                                    |    |
| Parameters - adjusting .....                | 6  |
| Polled words .....                          | 34 |
| <b>Q</b>                                    |    |
| Quick start chart SI-DeviceNet .....        | 17 |
| <b>R</b>                                    |    |
| Regenerating .....                          | 48 |
| Running at or below minimum speed .....     | 47 |
| <b>S</b>                                    |    |
| SI-DeviceNet cable shield connections ..... | 14 |
| SI-DeviceNet connections .....              | 13 |
| SI-DeviceNet network loss trip .....        | 50 |
| SI-DeviceNet terminal descriptions .....    | 12 |
| Spurs .....                                 | 15 |
| Status word .....                           | 47 |
| Stored charge .....                         | 6  |
| System design and safety of personnel ..... | 5  |
| <b>T</b>                                    |    |
| Termination .....                           | 14 |
| <b>W</b>                                    |    |
| Warnings .....                              | 5  |
| <b>Z</b>                                    |    |
| Zero speed .....                            | 47 |

|                         |
|-------------------------|
| Safety Information      |
| Introduction            |
| Mechanical Installation |
| Electrical Installation |
| Getting started         |
| Parameters              |
| Non cyclic data         |
| Control / status word   |
| EDS Files               |
| Advanced Features       |
| DeviceNet Objects       |
| Diagnostics             |
| Glossary/Of Terms       |
| <b>Index</b>            |



**0478-0032-02**